

# Colorado Department of Public Health and Environment

# **OPERATING PERMIT**

## **Peterson Air Force Base**

First Issued: March 3, 1998

# AIR POLLUTION CONTROL DIVISION COLORADO OPERATING PERMIT

FACILITY NAME: Peterson Air Force OPERATING PERMIT NUMBER

Base

FACILITY ID: 0410016

RENEWED: January 1, 2009 EXPIRATION DATE: January 1, 2014

MODIFICATIONS: See Appendix F of Permit

Issued in accordance with the provisions of Colorado Air Pollution Prevention and Control Act, 25-7-101 et

95OPEP147

seq. and applicable rules and regulations.

ISSUED TO: PLANT SITE LOCATION:

Peterson Air Force Base Peterson AFB

21 CES/CEV El Paso County, Colorado

580 Goodfellow Street Peterson AFB, CO 80914

INFORMATION RELIED UPON

Operating Permit Renewal Application Received: January 11, 2007 And Additional Information Received: July 31, 2007

Nature of Business: National Security

Primary SIC: 9711

RESPONSIBLE OFFICIAL FACILITY CONTACT PERSON

Name: John W. Raymond Name: Bob Tomlinson

Title: Colonel, USAF Title: Air Program Manager

Commander

Phone: 719-556-2100 Phone: 719-556-8059

Alternate: Wayne R. Monteith, Colonel

SUBMITTAL DEADLINES -

Semi-Annual Monitoring Period: January 1 - June 30; July 1 - December 31

Semi-Annual Monitoring Report: August 1, 2009 and February 1, 2010 and subsequent years

Annual Compliance Period: January 1 - December 31

Annual Compliance Certification: February 1, 2010 and subsequent years

Note that the Semi-Annual Monitoring Reports and Annual Compliance Certifications must be received at the Division office by 5:00 p.m. on the due date. Postmarked dates will not be accepted for the

purposes of determining the timely receipt of those reports/certifications.

## **TABLE OF CONTENTS:**

<b>SECTI</b>	ON I - General Activities and Summary	1
1.	Permitted Activities	
2.	Alternative Operating Scenarios	2
3.	Prevention of Significant Deterioration	
4.	Accidental Release Prevention Program (112(r))	2
5.	Compliance Assurance Monitoring (CAM)	2
6.	Summary of Emission Units	3
SECTI	ON II - Specific Permit Terms	5
1.	Bldg. 600 – Two Document Disintegrators with fabric filters (AIRS# 050).	
2.	Bldg 216 - Aircraft Parts Coating Paint Booth with Prep. Booth and Abrasive Blasting Room	
2	(AIRS# 065)	
3.		9
4.	Bldg. 2 – Three Cummins Model XTA50-69 Emergency Generators, 2020 hp each (AIRS# 047)	11
5.	Bldg. 1844 – One Cummins Model QSK60-G8 Emergency Generator, 2680 hp (AIRS# 053)	
6.	Bldg. 1840 – One Cummins Model QSK60-G8 Generator, 2,000 kw (AIRS# 057)	
7.	Bldg. 2 – One Cummins Model QSK60-G6 Generator, 2,600 hp (AIRS# 060)	
8.	Bldg. 2 – One Cummins Model QSK60-G6 Generator, 2,600 hp (AIRS# 061)	
9.	Bldg. 3 – One Cummins Model KTA 5D-G9 Emergency Generator, 2,220 hp each (AIRS# 064)	
10.	Bldg. 504 – One Cummins Model 4BT3.9-G4 Emergency Generator, 99 hp (AIRS# 066)	
11.	Bldg. 1334 – One Cummins Model QSL9-G2NR3 Emergency Generator, 364 hp (AIRS# 067)	
12.	Bldg. 920 – One Model SR-4 Emergency Generator, 1,100 kW (AIRS# 036).	
13.	AAFES Bldg 1360 - Four 10,000 Gallon Underground Storage Tanks (AIRS ID #029)	
13. 14.	AAFES Bldg 1700 – Tour 10,000 Gallon Underground Storage Tanks (AIRS ID#029)	
15.	Bldg 1232 – Two 15,000 Gallon Underground Gasoline Storage Tanks (AIRS ID#N/A)	
16.	Bldg 200 – Two 500 Gallon Gasoline Aboveground Storage Tanks (AIRS ID#N/A)	
17.	Base-Wide Hazardous Air Pollutant Emissions.	
1.	ON III - Permit Shield	
2.	General Conditions	50
3.	Stream-lined Conditions	
	ON IV - General Permit Conditions	
1.	Administrative Changes	
2.	Certification Requirements	
3.	Common Provisions	
3. 4.	Compliance Requirements	
4. 5.	Emergency Provisions	
5. 6.	Emission Standards for Asbestos	
6. 7.	Emission Standards for Aspestos  Emissions Trading, Marketable Permits, Economic Incentives	
7. 8.	Fee Payment	
o. 9.	Fugitive Particulate Emissions	
9. 10.	Inspection and Entry	
10.	Minor Permit Modifications	
	1,11101 1 TILLIN 1,10 MILLY WILLY WI	

## **TABLE OF CONTENTS:**

12.	New Source Review	58
13.	No Property Rights Conveyed	58
14.	Odor	58
15.	Off-Permit Changes to the Source	
16.	Opacity	59
17.	Open Burning	59
18.	Ozone Depleting Compounds	59
19.	Permit Expiration and Renewal	59
20.	Portable Sources	59
21.	Prompt Deviation Reporting	59
22.	Record Keeping and Reporting Requirements	60
23.	Reopenings for Cause	61
24.	Section 502(b)(10) Changes	61
25.	Severability Clause	61
26.	Significant Permit Modifications	62
27.	Special Provisions Concerning the Acid Rain Program	62
28.	Transfer or Assignment of Ownership	62
29.	Volatile Organic Compounds	62
30.	Wood Stoves and Wood burning Appliances	63
APPEN	NDIX A - Inspection Information	1
APPEN	NDIX C	1
Requir	ed Format for Annual Compliance Certification Reports	1
APPEN	NDIX D	1
Notif	fication Addresses	1
	NDIX E	
	nit Acronyms	
	NDIX F	
Perm	nit Modifications	1

## **SECTION I - General Activities and Summary**

#### 1. Permitted Activities

1.1 The primary mission of Peterson Air Force Base is space surveillance. This is accomplished through the use of sensors that detect, track and report on man-made objects in space, including active space systems and space debris. The Base receives and houses various sizes and types of aircraft and has an aeroclub. More than 6,000 military personnel are needed to operate the Base. There are 400 residential housing units and the support services needed for the convenience of the Base personnel.

Sources of emissions on the Base considered for this operating permit include approximately: 250 boilers, furnaces and hot water heaters; 38 emergency standby generators; 92 storage tanks; three refueling operations; a vehicle maintenance facility; 74 operational shops; an aircraft parts paint booth, an engine testing facility, paper disintegrators and routine aircraft maintenance activities.

The facility is located in the southeast part of Colorado Springs, El Paso County, Colorado. It is east of Powers Boulevard and immediately north of the Colorado Springs Municipal airport. The area in which the Base operates is classified as attainment/maintenance for carbon monoxide (CO), and attainment for all other criteria pollutants.

There are no affected states within 50 miles of the plant. There are no Federal Class I designated areas within 100 kilometers of the facility. Florissant Fossil Beds National Monument is a Federal land area within 100 kilometers of the facility. Florissant Fossil Beds has been designated by the State to have the same sulfur dioxide increment as a Federal Class I area.

- 1.2 Until such time as this permit expires or is modified or revoked, the permittee is allowed to discharge air pollutants from this facility in accordance with the requirements, limitations, and conditions of this permit.
- 1.3 The Operating Permit incorporates the applicable requirements contained in the underlying construction permits, and does not affect those applicable requirements, except as modified during review of the application or as modified subsequent to permit issuance using the modification procedures found in Regulation No. 3, Part C. These Part C procedures meet all applicable substantive New Source Review requirements of Part B. Any revisions made using the provisions of Regulation No. 3, Part C shall become new applicable requirements for purposes of this Operating Permit and shall survive reissuance. This permit incorporates the applicable requirements (except as noted in Section II) from the following construction permits:

96EP258-5	96EP258-6	02EP0111	02EP0197
02EP0495	02EP0692	03EP0724	04EP0397
04EP0398	05EP0962	06EP0511	89EP154-2

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- All conditions in this permit are enforceable by US Environmental Protection Agency, Colorado Air Pollution Control Division (hereinafter Division) and its agents, and citizens unless otherwise specified. **State-only enforceable conditions are:** Permit Condition Number(s): Section IV Conditions 3.d & 3.g (last paragraph), 14 & 18 (as noted).
- 1.5 All information gathered pursuant to the requirements of this permit is subject to the Recordkeeping and Reporting requirements listed under Condition 22 of the General Conditions in Section IV of this permit. Either electronic or hard copy records are acceptable.

## 2. Alternative Operating Scenarios

- 2.1 The permittee shall be allowed to make the following changes to its method of operation without applying for a revision of this permit.
- 2.2 No separate operating scenarios have been specified.

## 3. Prevention of Significant Deterioration

- This facility is located in an Area classified as attainment/maintenance for carbon monoxide (CO). Under that classification, all SIP-approved requirements for CO will continue to apply in order to prevent backsliding under the provisions of Section 110(l) of the Federal Clean Air Act. The facility is categorized as a major stationary source (Potential to Emit ≥ 250 Tons/Year for NO<sub>X</sub>). Future modifications at this facility resulting in a significant net emissions increase (see Reg 3, Part D, Sections II.A.26 and 42) for any pollutant as listed in Regulation No. 3, Part D, Section II.A.42 or a modification which is major by itself (i.e. a Potential to Emit of ≥ 250 TPY of any pollutant listed in Regulation No. 3, Part D, Section II.A.42) may result in the application of the PSD review requirements.
- 3.2 There are no other Operating Permits associated with this Base for the purposes of determining the applicability of the PSD regulations.

### 4. Accidental Release Prevention Program (112(r))

4.1 Based upon the information provided by the applicant, this facility is not subject to the provisions of the Accidental Release Prevention Program (Section 112(r) of the Federal Clean Air Act).

## **5.** Compliance Assurance Monitoring (CAM)

5.1 The following emission points at this facility use a control device to achieve compliance with an emission limitation or standard to which they are subject and have pre-control emissions that exceed or are equivalent to the major source threshold. They are therefore subject to the provisions of the CAM program as set forth in 40 CFR Part 64, as adopted by reference in Colorado Regulation No. 3, Part C, Section XIV:

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

None

#### **Summary of Emission Units 6.**

#### 6.1 The emissions units regulated by this permit are the following:

AIRS Point Number	Emission Unit Number	Description	Size	Construction Permit				
Electric Generators								
046	S046	Emergency generator - Cummins engine Model QST30-G1 w/ Onan generator 750DFHA; Serial Number 3179939 – Bldg 218.	850 HP / 600 KW	02EP0111				
047	S047	Three (3) emergency generators - Cummins Model XTA50-69 engine w/ model 1500 DFLE generators; Serial Numbers 25274158, 25275074 & 2524157 – Bldg 2.	2020 HP each	02EP0197				
053		Emergency generator - Cummins engine Model QSK60-G8, s/n: 33148537, w/ Cummins generator AST 2000 KW DQKC - Bldg 1844.	2680 HP	02EP0692				
057		Emergency generator - Cummins, diesel fueled, model QSK60-G8, s/n: 33147829, located at Bldg 1840.	2,000 kW	03EP0724				
060		Emergency generator - Cummins, diesel fueled, model QSK60-G6, s/n: 33156698, located at Bldg 2.	2,600 hp	04EP0397				
061		Emergency generator - Cummins, diesel fueled, model QSK60-G6, s/n: 33156633, located at Bldg 2.	2,600 hp	04EP0398				
064		Emergency generator - Cummins, diesel fueled, model KTA 50-G9, s/n: 25303866, located at Bldg 3.	2,220 hp	05EP0962				
066		Emergency Generator - Cummins, diesel fueled, model 4BT3.9-G4, s/n: 21790717, located at Bldg 504.	99 hp	N/A				
067		Emergency Generator - Cummins, diesel fueled, model QSL9-G2NR3, s/n: 21765399, located at Bldg 1334.	364 hp	N/A				
036		Emergency generator – Caterpillar, Model SR-4, Serial Number 24703082 – Bldg. 920.	1,100 kW	89EP154-2.XP				
Fuel Storage								
029	S029	Gasoline Service Station - Bldg 1360. With Stage I vapor recovery.	Four 10,000 gallon USTs	96EP258-5				
030	S030	Gasoline Service Station - Bldg 1700. With Stage I vapor recovery.	Three 10,00 gallon USTs	96EP258-6				
N/A	1232-R-1U & 1232-R-2U	Bldg. 1232 gasoline tanks.	Two 15,000 gallon USTs	N/A				
N/A	200-2A & 200-4A	Bldg. 200 gasoline tanks.	Two 500 gallon ASTs	N/A				

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

	Other Equipment & Activities								
050		Bldg 600 - Two document disintegrators, Disintegrator A = Model 1012, SN 38166 Disintegrator B = Model 22 SN 00480. With Fabric Filter.	A= 1200 lb/hr B= 450 lb/hr	02EP0495					
065		Paint booth with particulate filter & abrasive blasting.	N/A	06EP0511					
045	Facility-wide	HAP Limits	N/A	N/A					

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## **SECTION II - Specific Permit Terms**

1. Bldg. 600 – Two Document Disintegrators with fabric filters (AIRS# 050).

[Limits are total for both document disintegrators]

Parameter	Permit	Limit	ations	Compliance	Monito	ring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
PM	1.1		0.12 tons/yr	0.3 pounds of controlled emissions per ton of documents destroyed	Record keeping and calculation	Monthly
$PM_{10}$			0.12 tons/yr	0.3 pounds of controlled emissions per ton of documents destroyed		
Documents Processed	1.2		790 tons/year		Record keeping	Monthly
Opacity – Applies to Each Unit	1.3	Not to Exceed 20%			Method 9	Annually
	1.4		tional activities – ceed 30%			

1.1 Total Particulate Matter (PM) and Particulate Matter < 10  $\mu$ m (PM<sub>10</sub>) emissions from the document disintegrators shall not exceed the limitations stated in Summary Table 1 above (Construction Permit 02EP0495 as modified under the provisions of Section II, condition 1.3 and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). The emission factors listed above have been approved by the Division and shall be used to calculate emissions.

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

1.2 Total documents processed shall not exceed the limitation shown in Summary Table 1 above. (Construction Permit 02EP0495 as modified under the provisions of Section II, condition 1.3 and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 1.3 Except as provided in Condition 1.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - 1.3.1 If visible emissions, other than condensed moisture, persisting for more than fifteen (15) consecutive minutes are observed, the source of the problem shall be investigated and corrected. The results of the investigation and the correction(s) shall be logged and made available for Division review upon request. If the visible emissions persist after the correction(s) has been made, a Method 9 opacity observation shall be performed.
  - Once per calendar year, a Method 9 opacity observation shall be performed. An observer with a current and valid certification shall perform the Method 9 opacity observations. A clear and readable copy of the observer's certificate shall be kept on file with the copies of the observations. No Method 9 observation is required in any calendar year in which the unit does not operate for longer than 6 continuous minutes.
  - 1.3.3 If any Method 9 opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.
- 1.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 2. Bldg 216 - Aircraft Parts Coating Paint Booth with Prep. Booth and Abrasive Blasting Room (AIRS# 065).

Parameter	Permit	Li	mitations	Compliance	Monito	ring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
VOC	2.1		3.8 ton/yr	Mass balance	Record keeping and calculation	Monthly
Paint and Paint Material Usage	2.2				Record keeping	Monthly
Opacity	2.3	Not to Exceed 20%				
	2.4		erational activities – Exceed 30%			
Exhaust Filters	2.5	Exhaust filters required			Visual Inspection	As necessary
No Disposal By Evaporation	2.6					

2.1 Total Volatile Organic Compound (VOC) emissions from the paint booths shall not exceed the limitations stated in Summary Table 2 above (Construction Permit 06EP0511).

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month. A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

Current copies of the Material Safety Data Sheets (MSDS) or other equivalent composition data for the materials used shall be kept with the calculations. Records of the calculations and the compliance determinations shall be kept on-site and made available for Division review upon request.

- A record of the total paint and paint material usage for the paint booths shall be maintained and made available to the Division for review upon request. A twelve-month rolling total shall be maintained. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.
- 2.3 Except as provided in Condition 2.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).

In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

- 2.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.
- 2.5 The paint booth shall be equipped with exhaust filters or over spray arresters to minimize emissions of particulate matter. These filters and arresters shall be maintained/renewed as per the manufacturer's recommendations, or more often if needed, to assure on-going performance of the control devices. A record shall be kept of the maintenance/renewals performed. A copy of the manufacturer's recommendations and copies of the maintenance/renewal records shall be maintained on-site and made available for Division review upon request. Evidence of paint penetration of the control devices shall be considered evidence of non-compliance
- 2.6 No person shall dispose of volatile organic compounds by evaporation, or spillage unless Reasonably Available Control Technology (RACT) is utilized (Colorado Regulation No. 7, V.A.).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 3. Bldg. 218 – One Cummins QST30-G1 Emergency Generator, 850 hp (AIRS# 046).

Parameter	Permit	Limit	ations	Compliance	Monito	oring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	3.1		2.98 tons/yr	3.2 lb/MMBtu	Record keeping and calculation	Monthly
Fuel Use	3.2		13,600 gallons diesel/yr		Record keeping	Monthly
Opacity	3.3	Not to Exceed 20%		See Condi	ition 3.3	
	3.4	For certain operational activities – Not to Exceed 30%			See Condition 3.4	
Sulfur Dioxide	3.6	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

3.1 Total Nitrogen Oxide (NO<sub>X</sub>) emissions from the generator shall not exceed the limitations stated in Summary Table 3 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 13,600 gallons/yr identified in an APEN filed by the source dated 11/16/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

- 3.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 3 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 13,600 gallons/yr identified in an APEN filed by the source dated 11/16/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.
- 3.3 Except as provided in Condition 3.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

3.3.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

> If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

> Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 3.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - 3.4.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 3.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 3.4 have occurred.
- 3.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### 4. Bldg. 2 – Three Cummins Model XTA50-69 Emergency Generators, 2020 hp each (AIRS# 047).

[Limits are total for all engines]

Parameter	Permit	Limit	ations	Compliance	Monito	oring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	4.1		16.88 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			4.48 tons/yr	0.85 lb/MMBtu		
Fuel Use	4.2		77,000 gallons diesel/yr		Record keeping	Monthly
Opacity – Applies to Each	4.3	Not to Exceed 20%			See Condi	ition 4.3
Unit	4.4	For certain operational activities – Not to Exceed 30%			See Condition 4.4	
Sulfur Dioxide	4.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

4.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generators shall not exceed the limitations stated in Summary Table 4 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 77,000 gallons/yr identified in an APEN filed by the source dated 11/16/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

4.2 Total fuel use for the generators shall not exceed the limitation shown in Summary Table 4 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 77,000 gallons/yr identified in an APEN filed by the source dated 11/16/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 4.3 Except as provided in Condition 4.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - 4.3.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis for each generator. A second Method 9 reading shall be conducted if any generator consumes more than 25,900 gallons in any calendar year period. If two opacity readings are required, they must be conducted more than thirty days apart, unless approved in advance by the Division. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 4.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - 4.4.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis (per generator) and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 4.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 4.4 have occurred.
- 4.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 of credible evidence to the contrary, compliance with this  $SO_2$  emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 5. Bldg. 1844 – One Cummins Model QSK60-G8 Emergency Generator, 2680 hp (AIRS# 053).

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	5.1		7.67 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			2.04 tons/yr	0.85 lb/MMBtu		
Fuel Use	5.2		35,000 gallons diesel/yr		Record keeping	Monthly
Opacity	5.3	Not to Ex	ceed 20%		See Condi	ition 5.3
	5.4	For certain operational activities – Not to Exceed 30%		See Cond	See Condition 5.4	
Sulfur Dioxide	5.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

5.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generator shall not exceed the limitations stated in Summary Table 5 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 35,000 gallons/yr identified in an APEN filed by the source dated 11/17/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

5.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 5 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 35,000 gallons/yr identified in an APEN filed by the source dated 11/17/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 5.3 Except as provided in Condition 5.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 5.4 have occurred.
- 5.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 6. Bldg. 1840 – One Cummins Model QSK60-G8 Generator, 2,000 kw (AIRS# 057).

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	6.1		7.67 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			2.04 tons/yr	0.85 lb/MMBtu		
Fuel Use	6.2		35,000 gallons diesel/yr		Record keeping	Monthly
Opacity	6.3	Not to Exceed 20%			See Cond	ition 6.3
	6.4	For certain operational activities – Not to Exceed 30%			See Cond	ition 6.4
Sulfur Dioxide	6.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

6.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generator shall not exceed the limitations stated in Summary Table 6 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 35,000 gallons/yr identified in an APEN filed by the source dated 11/17/2006). The emission factors listed above (from AP-42 3.3 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

6.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 6 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 35,000 gallons/yr identified in an APEN filed by the source dated 11/17/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 6.3 Except as provided in Condition 6.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 6.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 6.4 have occurred.
- 6.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 7. Bldg. 2 – One Cummins Model QSK60-G6 Generator, 2,600 hp (AIRS# 060).

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	7.1		7.49 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			1.99 tons/yr	0.85 lb/MMBtu		
Fuel Use	7.2		34,150 gallons diesel/yr		Record keeping	Monthly
Opacity	7.3	Not to Exceed 20%			See Cond	ition 7.3
	7.4	For certain operational activities – Not to Exceed 30%			See Cond	ition 7.4
Sulfur Dioxide	7.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

7.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generator shall not exceed the limitations stated in Summary Table 7 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 34,150 gallons/yr identified in an APEN filed by the source dated 11/17/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

7.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 7 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 34,150 gallons/yr identified in an APEN filed by the source dated 11/17/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 7.3 Except as provided in Condition 7.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - 7.3.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 7.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - 7.4.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 7.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 7.4 have occurred.
- 7.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 8. Bldg. 2 – One Cummins Model QSK60-G6 Generator, 2,600 hp (AIRS# 061).

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	8.1		7.49 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			1.99 tons/yr	0.85 lb/MMBtu		
Fuel Use	8.2		34,150 gallons diesel/yr		Record keeping	Monthly
Opacity	8.3	Not to Exceed 20%			See Cond	ition 8.3
	8.4	For certain operational activities – Not to Exceed 30%			See Cond	ition 8.4
Sulfur Dioxide	8.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

8.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generator shall not exceed the limitations stated in Summary Table 8 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 34,150 gallons/yr identified in an APEN filed by the source dated 11/17/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

8.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 8 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 34,150 gallons/yr identified in an APEN filed by the source dated 11/17/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 8.3 Except as provided in Condition 8.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 8.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 8.4 have occurred.
- 8.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 9. Bldg. 3 – One Cummins Model KTA 5D-G9 Emergency Generator, 2,220 hp each (AIRS# 064).

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
NO <sub>x</sub>	9.1		5.68 tons/yr	3.20 lb/MMBtu	Record keeping and calculation	Monthly
СО			1.51 tons/yr	0.85 lb/MMBtu		
Fuel Use	9.2		25,900 gallons diesel/yr		Record keeping	Monthly
Opacity	9.3	Not to Exceed 20%			See Condition 9.3	
	9.4	For certain operational activities – Not to Exceed 30%			See Condi	tion 9.4
Sulfur Dioxide	9.5	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	
O&M Plan	9.6	Follow requirements of most recently approved plan			Per O&N	A Plan

9.1 Total Nitrogen Oxide (NO<sub>X</sub>) and Carbon Monoxide (CO) emissions from the generator shall not exceed the limitations stated in Summary Table 9 above (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 25,900 gallons/yr identified in an APEN filed by the source dated 11/17/2006). The emission factors listed above (from AP-42 3.4 10/96) have been approved by the Division and shall be used to calculate emissions from the generator, as follows:

Monthly emissions of each pollutant shall be calculated by the end of the subsequent month using the above emission factors and the monthly fuel use in the equation below:

Lb/mo = CEF (lb/MMBtu) x Fuel Use (gallons/mo) x Fuel Energy Content (MMBtu/gallon)

A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data.

9.2 Total fuel use for the generator shall not exceed the limitation shown in Summary Table 9 above. (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part A, Section I.B.36.h, and Part C, Section III.B.7 based on maximum fuel use rate of 25,900 gallons/yr identified in an APEN filed by the source dated 11/17/2006). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 9.3 Except as provided in Condition 9.4 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - 9.3.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis for each generator. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 9.4 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - 9.4.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 9.4.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 9.4 have occurred.
- 9.5 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.
- 9.6 The applicant shall follow the most current operating and maintenance plan and record keeping format approved by the Division in order to demonstrate compliance on an ongoing basis with

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

the requirements of condition no. 9.1 & 9.2 listed above (Construction Permit 05EP0962 as modified under the provisions of Section II, condition 1.3).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

## 10. Bldg. 504 – One Cummins Model 4BT3.9-G4 Emergency Generator, 99 hp (AIRS# 066).

Parameter	Permit	Limitations		Compliance	Monito	nitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval	
Operating Hours	10.1				Record keeping	Monthly	
Opacity	10.2	Not to Ex	Not to Exceed 20%		See Condition 10.2		
	10.3		For certain operational activities – Not to Exceed 30%		See Condition 10.3		
Sulfur Dioxide	10.4	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction		
NESHAP Subpart ZZZZ	10.5	Comply with NSPS Subpart IIII					
NSPS Subpart IIII	10.6	NO <sub>X</sub> + NMHC – 5.59 g/hp-hr CO – 3.73 g/hp-hr PM – 0.30 g/hp-hr Smoke Emission Standards (Condition 10.5.1) Fuel Requirements (Conditions 10.5.3 & 10.5.4)			See Condition 10.6		

- 10.1 Total operating hours for the generator shall recorded on a monthly basis. A twelve-month rolling total shall be maintained. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.
- 10.2 Except as provided in Condition 10.3 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. A second Method 9 reading shall be conducted if the generator is operated more than 250 hours in any calendar year period. If two opacity readings are required, they must be conducted more than thirty days apart, unless approved in advance by the Division. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 10.3 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 10.3.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 10.3 have occurred.
- 10.4 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with the SO<sub>2</sub> emission limitation shall be presumed since only diesel fuel meeting the requirements in Conditions 10.5.3 and 10.5.4 is permitted to be used as fuel in this engine.
- 10.5 This source is subject to the requirements of 40 CFR Part 63, Subpart ZZZZ National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, including, but not limited to, the following: [Federal Only]
  - An affected source that is a new or reconstructed stationary RICE located at an area source must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part (40 CFR Part 63, §63.6590(c)).
- 10.6 This engine is subject to the requirements in 40 CFR Part 60 Subpart IIII, "Standards of Performance for Stationary Compression Ignition Internal Combustion Engines", as adopted by reference in Colorado Regulation No. 6, Part A, including but not limited to the following requirements:

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4205)

10.6.1 Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE. (§ 60.4205(b))

> Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section. (§ 60.4202(a))

> For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007. (§ 60.4202(a)(2))

> The specific emission limitations in 40 CFR 89.112 that apply to this unit are as follows:

	Tier 2 requirements for Model Engines $37 \le kW < 75$						
Emiss	ion Standards (g/k	W-hr)	Emission Standards (g/hp-hr)				
NMHC + NOX	CO	PM	NMHC + NOX	CO	PM		
7.5	5.0	0.4	5.59	3.73	0.30		

The applicable smoke emission standards in 40 CFR 89.113 that apply to this unit are as follows:

Smoke Emission Standard	Operating Mode
20 % opacity	Acceleration Mode
15% opacity	Lugging Mode
50 % opacity	Peaks in Either the Acceleration or Lugging Modes

How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4206)

Owners and operators of stationary CI ICE must operate and maintain stationary CI 10.6.2 ICE that achieve the emission standards as required in §§60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart? (§ 60.4207)

10.6.3 Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a). (§ 60.4207(a))

> The fuel limitations in 80.510(a) are: sulfur content of 500 parts per million (ppm), maximum and a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent.

10.6.4 Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel. ((§ 60.4207(a))

> The fuel limitations in 80.510(b) are: sulfur content of 15 ppm maximum for NR diesel fuel and 500 ppm maximum for LM diesel fuel and a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent.

> The diesel fuel in the engine's day tank shall be sampled and analyzed within 60 days of permit issuance to determine the sulfur and cetane and/or aromatic content using appropriate ASTM methods, or equivalent if approved in advance by the Division. If the tank is empty prior to permit issuance, sampling of the day tank is not required, compliance shall be monitored by sampling each shipment of diesel fuel as specified below.

> Thereafter compliance with the fuel limitations shall be monitored by sampling and analyzing each shipment of diesel fuel to determine the sulfur and cetane and/or aromatic content using appropriate ASTM methods, or equivalent if approved in advance by the Division. In lieu of sampling, vendor data may be used to determine the sulfur and cetane and/or aromatic content, provided that the sampling and analysis was performed using the appropriate ASTM methods.

What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4209)

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

- 10.6.5 If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine. (§ 60.4209(a))
- 10.6.6 If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 \$60,4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached. (§ 60.4209(b))

What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4211)

- 10.6.7 If you are an owner or operator and must comply with the emission standards specified in this subpart, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you. (§ 60.4211(a))
- 10.6.8 If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications. (§ 60.4211(c))
- 10.6.9 Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited. (§ 60.4211(e))

What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4214)

10.6.10 If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. (§ 60.4214(b))

10.6.11 If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached. (§ 60.4214(c))

What parts of the general provisions apply to me? (§ 60.4218)

- 10.6.12 Table 8 of this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you. (§ 60.4218)
- 10.7 In addition, the following requirements of Regulation No. 6, Part A, Subpart A, General Provisions, apply.

No article, machine, equipment or process shall be used to conceal an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere. (§ 60.12)

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# 11. Bldg. 1334 – One Cummins Model QSL9-G2NR3 Emergency Generator, 364 hp (AIRS# 067).

Parameter	Permit	Limitations		Compliance	Monito	oring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
Operating Hours	11.1				Record keeping	Monthly
Opacity	11.2	Not to Ex	ceed 20%		See Condition 11.2	
	11.3	For certain operational activities – Not to Exceed 30%			See Condition 11.3	
Sulfur Dioxide	11.4	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	
NESHAP Subpart ZZZZ	11.5	Comply with NSPS IIII				
NSPS Subpart IIII	11.6	NO <sub>X</sub> + NMHC – 2.984 g/hp-hr CO – 2.61 g/hp-hr PM – 0.15 g/hp-hr Smoke Emission Standards (Condition 11.5.1) Fuel Requirements (Conditions 11.5.3 & 11.5.4)			See Condit	tion 11.6

- 11.1 Total operating hours for the generator shall recorded on a monthly basis. A twelve-month rolling total shall be maintained. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.
- 11.2 Except as provided in Condition 11.3 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. A second Method 9 reading shall be conducted if the generator is operated more than 250 hours in any calendar year period. If two opacity readings are required, they must be conducted more than thirty days apart, unless approved in advance by the Division. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an

exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

- 11.3 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
  - 11.3.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 11.3 have occurred.
- 11.4 Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with the SO<sub>2</sub> emission limitation shall be presumed since only diesel fuel meeting the requirements in Conditions 11.5.3 and 11.5.4 is permitted to be used as fuel in this engine.
- 11.5 This source is subject to the requirements of 40 CFR Part 63, Subpart ZZZZ National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, including, but not limited to, the following: [Federal Only]
  - An affected source that is a new or reconstructed stationary RICE located at an area source must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part (40 CFR Part 63, §63.6590(c)).
- 11.6 This engine is subject to the requirements in 40 CFR Part 60 Subpart IIII, "Standards of Performance for Stationary Compression Ignition Internal Combustion Engines", as adopted by reference in Colorado Regulation No. 6, Part A, including but not limited to the following requirements:

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4205)

1161 Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE. (§ 60.4205(b))

> Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section. (§ 60.4202(a))

> For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007. (§ 60.4202(a)(2))

> The specific emission limitations in 40 CFR 89.112 that apply to this unit are as follows:

	Tier 3 requirements for Model Engines $225 \le kW < 450$						
Emiss	sion Standards (g/k	W-hr)	Emission Standards (g/hp-hr)				
NMHC + NOX	CO	PM	NMHC + NOX	CO	PM		
4.0	3.5	0.2	2.984	2.61	0.15		

The applicable smoke emission standards in 40 CFR 89.113 that apply to this unit are as follows:

Smoke Emission Standard	Operating Mode
20 % opacity	Acceleration Mode
15% opacity	Lugging Mode
50 % opacity	Peaks in Either the Acceleration or Lugging Modes

How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4206)

11.6.2 Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart? (§ 60.4207)

11 6 3 Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a). (§ 60.4207(a))

> The fuel limitations in 80.510(a) are: sulfur content of 500 parts per million (ppm), maximum and a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent.

11.6.4 Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel. ((§ 60.4207(a))

> The fuel limitations in 80.510(b) are: sulfur content of 15 ppm maximum for NR diesel fuel and 500 ppm maximum for LM diesel fuel and a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent.

> The diesel fuel in the engine's day tank shall be sampled and analyzed within 60 days of permit issuance to determine the sulfur and cetane and/or aromatic content using appropriate ASTM methods, or equivalent if approved in advance by the Division. If the tank is empty prior to permit issuance, sampling of the day tank is not required, compliance shall be monitored by sampling each shipment of diesel fuel as specified below.

> Thereafter compliance with the fuel limitations shall be monitored by sampling and analyzing each shipment of diesel fuel to determine the sulfur and cetane and/or aromatic content using appropriate ASTM methods, or equivalent if approved in advance by the Division. In lieu of sampling, vendor data may be used to determine the sulfur and cetane and/or aromatic content, provided that the sampling and analysis was performed using the appropriate ASTM methods.

What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4209)

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

- 11.6.5 If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine. (§ 60.4209(a))
- 1166 If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 \$60,4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached. (§ 60.4209(b))

What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4211)

- 11.6.7 If you are an owner or operator and must comply with the emission standards specified in this subpart, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you. (§ 60.4211(a))
- 11.6.8 If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications. (§ 60.4211(c))
- 11.6.9 Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited. (§ 60.4211(e))

What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine? (§ 60.4214)

11.6.10 If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time. (§ 60.4214(b))

11.6.11 If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached. (§ 60.4214(c))

What parts of the general provisions apply to me? (§ 60.4218)

- 11.6.12 Table 8 of this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you. (§ 60.4218)
- In addition, the following requirements of Regulation No. 6, Part A, Subpart A, General 11.7 Provisions, apply.
  - 11.7.1 No article, machine, equipment or process shall be used to conceal an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere. (§ 60.12)

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# 12. Bldg. 920 – One Model SR-4 Emergency Generator, 1,100 kW (AIRS# 036).

Parameter	Permit	Limita	ations	Compliance	Monito	oring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
Operating Hours	12.1		250 hours/yr		Record keeping	Monthly
Opacity	12.2	Not to Exceed 20%			See Condition 12.2	
	12.3	For certain operational activities – Not to Exceed 30%			See Condit	tion 12.3
Sulfur Dioxide	12.4	0.8 pounds of SO <sub>2</sub> per million BTU of oil heat input			Fuel restriction	

- 12.1 Total operating hours for the generator shall not exceed 250 hours per year. Total operating hours for the generator shall recorded on a monthly basis. A twelve-month rolling total shall be maintained. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data.
- 12.2 Except as provided in Condition 12.3 below, no owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.

If any of the opacity observations exceed the applicable standard, additional observations must be performed. Subject to the provisions of §25-7-123.1, C.R.S., and in the absence of credible evidence to the contrary, exceedance of the limit shall be considered to exist from the time a Method 9 reading is taken that shows an exceedance of the opacity limit until a Method 9 reading is taken that shows the opacity is less than the opacity limit.

Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned.

12.3 No owner or operator of a source shall allow or cause to be emitted into the atmosphere any air pollutant resulting from the building of a new fire, cleaning of fire boxes, soot blowing, start-up, any process modification, or adjustment or occasional cleaning of control equipment, which is in excess of 30% opacity for a period or periods aggregating more than six (6) minutes in any sixty (60) consecutive minutes (Colorado Regulation No. 1, Section II.A.4).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 12.3.1 When burning No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels, compliance with this standard shall be monitored by conducting emission observations in accordance with EPA Method 9. One Method 9 reading shall be conducted on a calendar year basis and shall be taken within one hour of the commencement of one of the above specific activities and every 24 hours thereafter until the specific activity has been completed. Results of Method 9 readings and a copy of the certified Method 9 reader's certification shall be made available to the Division upon request.
- 12.3.2 Visible emissions observations are not required for any calendar year period where no No. 2 fuel oil, JP-8, biodiesel, and other distillate fuels have been burned, or if no specific activities identified in Condition 12.3 have occurred.
- Sulfur Dioxide (SO<sub>2</sub>) emissions from the generator shall not exceed 0.8 pounds of SO<sub>2</sub> per 12.4 million BTU of oil heat input (Colorado Regulation No. 1, Section VI.B.4.b(i)). In the absence of credible evidence to the contrary, compliance with this SO<sub>2</sub> emission limitation is presumed while No. 2 diesel fuel is used to fuel the generator.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# 13. AAFES Bldg 1360 - Four 10,000 Gallon Underground Storage Tanks (AIRS ID #029)

[The following terms and conditions apply to the combined operation of the four (4) storage tanks]

Parameter	Permit	Limit	ations	Compliance	Monito	ring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
VOC	13.1		24.57 tons/yr	11.7 pounds per thousand gallons of throughput	Record keeping and calculation	Monthly
Fuel Throughput	13.2		4.2 million gallons gasoline per year		Vendor Receipts, flow meter readings and record of inventory on hand	Monthly
Opacity – Applies to Each Unit	13.3	Not to Exceed 20%			Fuel Restriction	
National Emission Standards for Hazardous Air Pollutants	13.4	Submerged Filling Vapor Balance System Management Practices			Specific Compliance Testing	Every 3 Years

- 13.1 Total Volatile Organic Compound (VOC) emissions shall not exceed the limitations stated in Summary Table 13 above (as provided for under the provisions of Section I, Condition 1.3 of this Operating Permit and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data. The calculations and compliance determinations shall be kept on file and made available for Division review upon request.
- Total gasoline throughput in the storage tanks shall not exceed the limitation shown in Summary Table 13 above (as provided for under the provisions of Section I, Condition 1.3 of this Operating Permit and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data. The calculations and compliance determinations shall be kept on file and made available for Division review upon request.
- No owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.
- 13.4 This source is subject to the requirements of 40 CFR Part 63, Subpart CCCCCC National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities, including, but not limited to, the following: [Federal Only]

- 13.4.1 The affected sources at this gasoline dispensing facility (GDF) (each gasoline cargo tank during the delivery of product to a GDF and also includes each storage tank. The equipment used for the refueling of motor vehicles is not covered by this subpart) are considered existing sources per §63.11112, and the compliance date is January 10, 2011 per §63.11113;
- 13.4.2 Gasoline must not be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include §63.11116(a)(1) through (4);
- 13.4.3 Gasoline shall only be loaded into the storage tanks by utilizing submerged filling. Submerged fill pipes must be no more than 12 inches from the bottom of the tank. (Reference §63.11117(b));
- 13.4.4 The GDF must comply with each management practice in Table 1 of this subpart that applies to your GDF (Reference §63.11118(b)(1));
- 13.4.5 Cargo tanks unloading at this GDF must comply with the management practices in Table 2 of this subpart (Reference §63.11118(d));
- You must demonstrate compliance with the leak rate and cracking pressure 13.4.6 requirements, specified in item 1(g) of Table 1 of this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(1));
- 13.4.7 You must demonstrate compliance with the static pressure performance requirement, specified in item 1(h) of Table 1 to this subpart, for your vapor balance system by conducting a static pressure test on your gasoline storage tanks using the test methods identified in paragraph (a)(2)(i) or (a)(2)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(2));
- 13.4.8 An Initial Notification shall be submitted per §63.11124(a)(1);
- 13.4.9 A Notification of Compliance Status must be submitted per §63.11124(a)(2);
- 13.4.10 An Initial Notification shall be submitted per §63.11124(b)(1);
- 13.4.11 A Notification of Compliance Status must be submitted per §63.11124(b)(2):
- 13.4.12 A Notification of Performance Test shall be submitted per §63.11124(b)(4);
- 13.4.13 Records of all tests performed under §63.11120(a) & (b) must be kept for a period of five years and shall be made available for inspection by the Division upon request (Reference §63.11125(a) & (b));

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- Reports of the results of all volumetric efficiency tests required under §63.11120(b) 13.4.14 shall be submitted to the Administrator within 180 days of the completion of the performance testing (Reference §63.11126);
- The applicable General Provisions are listed in Table 3 of this Subpart. 13.4.15

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### 14. AAFES Bldg 1700 – Three 10,000 Gallon Underground Storage Tanks (AIRS ID#030)

[The following terms and conditions apply to the combined operation of the three (3) storage tanks]

Parameter	Permit	Limit	ations	Compliance	Monito	ring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
VOC	14.1		29.84 tons/yr	11.7 pounds per thousand gallons of throughput	Record keeping and calculation	Monthly
Fuel Throughput	14.2		5.1 million gallons gasoline per year		Vendor Receipts, flow meter readings and record of inventory on hand	Monthly
Opacity – Applies to Each Unit	14.3	Not to Exceed 20%			Fuel Restriction	
National Emission Standards for Hazardous Air Pollutants	14.4	Submerged Filling Vapor Balance System Management Practices			Specific Compliance Testing	Every 3 Years

- 14.1 Total Volatile Organic Compound (VOC) emissions shall not exceed the limitations stated in Summary Table 14 above (as provided for under the provisions of Section I, Condition 1.3 of this Operating Permit and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). A twelve-month rolling total of emissions will be maintained in order to monitor compliance with the annual emission limitation. By the end of each month, a new twelve-month total shall be calculated using the previous twelve months' data. The calculations and compliance determinations shall be kept on file and made available for Division review upon request.
- 14.2 Total gasoline throughput in the storage tanks shall not exceed the limitation shown in Summary Table 14 above (as provided for under the provisions of Section I, Condition 1.3 of this Operating Permit and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X). A twelve-month rolling total shall be maintained for demonstration of compliance with the annual limitation. By the end of each month a new twelve-month total shall be calculated using the previous twelve months' data. The calculations and compliance determinations shall be kept on file and made available for Division review upon request.
- 14.3 No owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.
- 14.4 This source is subject to the requirements of 40 CFR Part 63, Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities, including, but not limited to, the following: [Federal Only]

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 14.4.1 The affected sources at this gasoline dispensing facility (GDF) (each gasoline cargo tank during the delivery of product to a GDF and also includes each storage tank. The equipment used for the refueling of motor vehicles is not covered by this subpart) are considered existing sources per §63.11112, and the compliance date is January 10, 2011 per §63.11113;
- 14.4.2 Gasoline must not be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include §63.11116(a)(1) through (4);
- 14.4.3 Gasoline shall only be loaded into the storage tanks by utilizing submerged filling. Submerged fill pipes must be no more than 12 inches from the bottom of the tank. (Reference §63.11117(b));
- 14.4.4 The GDF must comply with each management practice in Table 1 of this subpart that applies to your GDF (Reference §63.11118(b)(1));
- Cargo tanks unloading at this GDF must comply with the management practices in 14.4.5 Table 2 of this subpart (Reference §63.11118(d));
- You must demonstrate compliance with the leak rate and cracking pressure 14.4.6 requirements, specified in item 1(g) of Table 1 of this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(1));
- 14.4.7 You must demonstrate compliance with the static pressure performance requirement, specified in item 1(h) of Table 1 to this subpart, for your vapor balance system by conducting a static pressure test on your gasoline storage tanks using the test methods identified in paragraph (a)(2)(i) or (a)(2)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(2));
- 14.4.8 An Initial Notification shall be submitted per §63.11124(a)(1);
- 14.4.9 A Notification of Compliance Status must be submitted per §63.11124(a)(2);
- An Initial Notification shall be submitted per §63.11124(b)(1); 14.4.10
- 14.4.11 A Notification of Compliance Status must be submitted per §63.11124(b)(2):
- 14.4.12 A Notification of Performance Test shall be submitted per §63.11124(b)(4);
- 14.4.13 Records of all tests performed under §63.11120(a) & (b) must be kept for a period of five years and shall be made available for inspection by the Division upon request (Reference §63.11125(a) & (b));

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- 14.4.14 Reports of the results of all volumetric efficiency tests required under §63.11120(b) shall be submitted to the Administrator within 180 days of the completion of the performance testing (Reference §63.11126);
- 14.4.15 The applicable General Provisions are listed in Table 3 of this Subpart.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# 15. Bldg 1232 – Two 15,000 Gallon Underground Gasoline Storage Tanks (AIRS ID#N/A)

Parameter	Permit	Limitations		Compliance	Monito	oring
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
Opacity – Applies to Each Unit	15.1	Not to Exc	eed 20%		Fuel Restriction	
National Emission Standards for Hazardous Air Pollutants	15.2	Submerged Filling Vapor Balance System Management Practices			Specific Compliance Testing	Every 3 Years

- No owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.
- 15.2 This source is subject to the requirements of 40 CFR Part 63, Subpart CCCCCC National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities, including, but not limited to, the following: [Federal Only]
  - The affected sources at this gasoline dispensing facility (GDF) (each gasoline cargo tank during the delivery of product to a GDF and also includes each storage tank. The equipment used for the refueling of motor vehicles is not covered by this subpart) are considered existing sources per §63.11112, and the compliance date is January 10, 2011 per §63.11113;
  - Gasoline must not be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include §63.11116(a)(1) through (4);
  - Gasoline shall only be loaded into the storage tanks by utilizing submerged filling. Submerged fill pipes must be no more than 12 inches from the bottom of the tank. (Reference §63.11117(b));
  - The GDF must comply with each management practice in Table 1 of this subpart that applies to your GDF (Reference §63.11118(b)(1));
  - Cargo tanks unloading at this GDF must comply with the management practices in Table 2 of this subpart (Reference §63.11118(d));
  - 15.2.6 You must demonstrate compliance with the leak rate and cracking pressure requirements, specified in item 1(g) of Table 1 of this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

- in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(1));
- 1527 You must demonstrate compliance with the static pressure performance requirement, specified in item 1(h) of Table 1 to this subpart, for your vapor balance system by conducting a static pressure test on your gasoline storage tanks using the test methods identified in paragraph (a)(2)(i) or (a)(2)(ii) of this section. This demonstration shall be conducted every 3 years. (Reference §63.11120(a)(2));
- 15.2.8 An Initial Notification shall be submitted per §63.11124(a)(1);
- 15.2.9 A Notification of Compliance Status must be submitted per §63.11124(a)(2);
- 15 2 10 An Initial Notification shall be submitted per §63.11124(b)(1);
- 15.2.11 A Notification of Compliance Status must be submitted per §63.11124(b)(2):
- 15.2.12 A Notification of Performance Test shall be submitted per §63.11124(b)(4);
- 15 2 13 Records of all tests performed under §63.11120(a) & (b) must be kept for a period of five years and shall be made available for inspection by the Division upon request (Reference §63.11125(a) & (b));
- 15.2.14 Reports of the results of all volumetric efficiency tests required under §63.11120(b) shall be submitted to the Administrator within 180 days of the completion of the performance testing (Reference §63.11126);
- 15.2.15 The applicable General Provisions are listed in Table 3 of this Subpart.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### Bldg 200 – Two 500 Gallon Gasoline Aboveground Storage Tanks (AIRS ID#N/A) **16.**

Parameter	Permit	Limitations		Compliance	Monitoring	
	Condition Number	Short Term	Long Term	Emission Factor	Method	Interval
Opacity – Applies to Each Unit	16.1	Not to Ex-	ceed 20%		Fuel Restriction	
National Emission Standards for Hazardous Air Pollutants	16.2	Gasoline Hand	lling Practices			

- 16.1 No owner or operator of a source shall allow or cause the emission into the atmosphere of any air pollutant which is in excess of 20% opacity. (Colorado Regulation No. 1, II.A.1).
  - In the absence of credible evidence to the contrary, compliance with the opacity limit shall be presumed based on the type of materials used and the method of operation.
- 16.2 This source is subject to the requirements of 40 CFR Part 63, Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities, including, but not limited to, the following: [Federal Only]
  - 1621 The affected sources at this gasoline dispensing facility (GDF) (each gasoline cargo tank during the delivery of product to a GDF and also includes each storage tank. The equipment used for the refueling of motor vehicles is not covered by this subpart) are considered existing sources per §63.11112, and the compliance date is January 10, 2011 per §63.11113;
  - 16.2.2 Gasoline must not be handled in a manner that would result in vapor releases to the Measures to be taken include atmosphere for extended periods of time. §63.11116(a)(1) through (4);
  - 16.2.3 The applicable General Provisions are listed in Table 3 of this Subpart.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### **17. Base-Wide Hazardous Air Pollutant Emissions.**

Parameter	Permit Condition Number	Limitations Short Term Long Term		Compliance Emission Factor	Monito Method	ring Interval
Hazardous Air Pollutants (HAPs)	17.1		Any Single HAP: 10.0 tons/yr Total HAPs: 25.0 tons/yr		Record keeping and calculation	Annual

17.1 The emissions shall be reviewed to verify the Base remains a minor source of HAPs with no single HAP emission greater than 10 tons per year, and total HAP emissions less than 25 tons per year. The calculations and the minor source verification shall be kept on file and available for Division review upon request.

The estimated Base-wide actual annual emissions of each HAP for the previous calendar year shall be calculated and reported on an APEN by April 30 of each new calendar year for emission fee payment in accordance with the provisions of Colorado Regulation No. 3, Part A, Section II.

The requirement for monitoring the HAP emissions was established directly in this Operating Permit as a combined Construction/Operating Permit (as provided for under the provisions of Section I, Condition 1.3 and Colorado Regulation No. 3, Part B, Section III.A.6 and Part C, Section X).

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# **SECTION III - Permit Shield**

# Regulation No. 3, 5 CCR 1001-5, Part C, §§ I.A.4, V.D. & XIII.B; § 25-7-114.4(3)(a), C.R.S.

# 1. Specific Non-Applicable Requirements

Based on the information available to the Division and supplied by the applicant, the following parameters and requirements have been specifically identified as non-applicable to the facility to which this permit has been issued. This shield does not protect the source from any violations that occurred prior to or at the time of permit issuance. In addition, this shield does not protect the source from any violations that occur as a result of any modifications or reconstruction on which construction commenced prior to permit issuance.

Emission Unit Description & Number	Applicable Requirement	Justification
S015 Jet Engine Testing	Regulation No. 6, Part B.I & II and IV	This source was built before January 30,1979. Further, jet engines are not considered fuel burning equipment subject to the provisions cited.
Flightline Maintenance at Bldg 214  Structural Repair at Bldg 216  Isodock Shop at Bldg 214  Bldg 625 Paint Booth	Regulation No. 7, all except for Section V.A.	Regulation 7 applies only to ozone non-attainment areas. The Base is in an ozone attainment area. Regulation 7, Sections VI.B.1 and 2 and VII.C apply statewide; however, this emission unit is not involved in the storage and transfer of petroleum liquids or crude oil. Regulation 7, Section V.B applies statewide but this emission unit is not a gasoline dispensing facility.
Isodock Shop at Bldg 214	40 CFR 63, Subpart GG as adopted in Regulation No. 6, Part A	This source uses only extremely low volumes of paint (less than 50 gallons per year), and is, therefore, exempt from the provisions of this regulation.
Facility-Wide	Regulation No. 1, Part III.D.2a(i)B	There is insufficient vehicle traffic on unpaved roads to require a fugitive emissions control plan.
	Regulation No. 7, All subparts except V and VI.B.2(a) & (b)	The Base is located in an ozone attainment area, has no external floating roof tanks, and does not store crude oil.
	40 CFR 60.30, Subpart Ca40 CFR 60.50a, Subpart F	There are no municipal waste combustors on the Base.
	40 CFR 60.40, Subpart D	All fossil-fuel fired steam generators built after August 17, 1971, are less than the threshold size limits.
	40 CFR 60.40a, Subpart Da	There are no electric utility steam generating units greater than the threshold size.
	40 CFR 60.40b, Subpart Db	There are no steam generating units greater than the threshold size.

	40 CFR 60.40c, Subpart Dc	There are no steam generating units greater than the threshold size.			
	40 CFR 60.50, Subpart E	There are no incinerators greater than the threshold size.			
	40 CFR 60.110, Subpart K	No petroleum liquid storage vessels greater than the threshold size constructed, reconstructed, or modified between June 11, 1973 and May 19, 1978.			
	40 CFR 60.110a, Subpart Ka	No petroleum liquid storage vessels greater than the threshold size constructed, reconstructed, or modified between May 18, 1978 and July 23, 1984.			
	40 CFR 60.110b, Subpart Kb, all parts except 60.116b(b)	The liquid contained is below the threshold vapor pressure of 3.5 KPa.			
	40 CFR 60.500, Subpart XX 40 CFR 63.420, Subpart R	The Base is not a bulk gasoline terminal			
Bldg 216 Aircraft Parts Coating Paint Booth	40 CFR 63, Subpart GG, Aerospace Maximum Achievable Control Technology	The Base-wide hazardous air pollutants are less than the major source threholds of 10/25 tons per year.			

#### 2. General Conditions

Compliance with this Operating Permit shall be deemed compliance with all applicable requirements specifically identified in the permit and other requirements specifically identified in the permit as not applicable to the source. This permit shield shall not alter or affect the following:

- 2.1 The provisions of §§ 25-7-112 and 25-7-113, C.R.S., or § 303 of the federal act, concerning enforcement in cases of emergency;
- 2.2 The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- 2.3 The applicable requirements of the federal Acid Rain Program, consistent with § 408(a) of the federal act;
- 2.4 The ability of the Air Pollution Control Division to obtain information from a source pursuant to § 25-7-111(2)(I), C.R.S., or the ability of the Administrator to obtain information pursuant to § 114 of the federal act;
- 2.5 The ability of the Air Pollution Control Division to reopen the Operating Permit for cause pursuant to Regulation No. 3, Part C, § XIII.
- 2.6 Sources are not shielded from terms and conditions that become applicable to the source subsequent to permit issuance.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# 3. Stream-lined Conditions

The following applicable requirements have been subsumed within this operating permit using the pertinent streamlining procedures approved by the U.S. EPA. For purposes of the permit shield, compliance with the listed permit conditions will also serve as a compliance demonstration for purposes of the associated subsumed requirements.

No applicable requirements were streamlined out of this permit.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### **SECTION IV - General Permit Conditions**

#### 1. **Administrative Changes**

# Regulation No. 3, 5 CCR 1001-5, Part A, § III.

The permittee shall submit an application for an administrative permit amendment to the Division for those permit changes that are described in Regulation No. 3, Part A, § I.B.1. The permittee may immediately make the change upon submission of the application to the Division.

#### 2. **Certification Requirements**

#### Regulation No. 3, 5 CCR 1001-5, Part C, §§ III.B.9., V.C.16.a.& e. and V.C.17.

- Any application, report, document and compliance certification submitted to the Air Pollution Control Division pursuant to Regulation No. 3 or the Operating Permit shall contain a certification by a responsible official of the truth, accuracy and completeness of such form, report or certification stating that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.
- All compliance certifications for terms and conditions in the Operating Permit shall be submitted to the Air Pollution b. Control Division at least annually unless a more frequent period is specified in the applicable requirement or by the Division in the Operating Permit.
- Compliance certifications shall contain: c.
  - (i) the identification of each permit term and condition that is the basis of the certification;
  - the compliance status of the source; (ii)
  - whether compliance was continuous or intermittent; (iii)
  - method(s) used for determining the compliance status of the source, currently and over the reporting (iv) period; and
  - such other facts as the Air Pollution Control Division may require to determine the compliance status of the (v) source.
- All compliance certifications shall be submitted to the Air Pollution Control Division and to the Environmental d. Protection Agency at the addresses listed in Appendix D of this Permit.
- If the permittee is required to develop and register a risk management plan pursuant to § 112(r) of the federal act, the e. permittee shall certify its compliance with that requirement; the Operating Permit shall not incorporate the contents of the risk management plan as a permit term or condition.

#### **Common Provisions** 3.

# Common Provisions Regulation, 5 CCR 1001-2 §§ II.A., II.B., II.C., II, E., II.F., II.I, and II.J

To Control Emissions Leaving Colorado

When emissions generated from sources in Colorado cross the State boundary line, such emissions shall not cause the air quality standards of the receiving State to be exceeded, provided reciprocal action is taken by the receiving State.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### b. Emission Monitoring Requirements

The Division may require owners or operators of stationary air pollution sources to install, maintain, and use instrumentation to monitor and record emission data as a basis for periodic reports to the Division.

#### c. Performance Testing

The owner or operator of any air pollution source shall, upon request of the Division, conduct performance test(s) and furnish the Division a written report of the results of such test(s) in order to determine compliance with applicable emission control regulations.

Performance test(s) shall be conducted and the data reduced in accordance with the applicable reference test methods unless the Division:

- (i) specifies or approves, in specific cases, the use of a test method with minor changes in methodology;
- (ii) approves the use of an equivalent method;
- (iii) approves the use of an alternative method the results of which the Division has determined to be adequate for indicating where a specific source is in compliance; or
- (iv) waives the requirement for performance test(s) because the owner or operator of a source has demonstrated by other means to the Division's satisfaction that the affected facility is in compliance with the standard. Nothing in this paragraph shall be construed to abrogate the Commission's or Division's authority to require testing under the Colorado Revised Statutes, Title 25, Article 7, and pursuant to regulations promulgated by the Commission.

Compliance test(s) shall be conducted under such conditions as the Division shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Division such records as may be necessary to determine the conditions of the performance test(s). Operations during period of startup, shutdown, and malfunction shall not constitute representative conditions of performance test(s) unless otherwise specified in the applicable standard.

The owner or operator of an affected facility shall provide the Division thirty days prior notice of the performance test to afford the Division the opportunity to have an observer present. The Division may waive the thirty day notice requirement provided that arrangements satisfactory to the Division are made for earlier testing.

The owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:

- i. Sampling ports adequate for test methods applicable to such facility;
- (v) Safe sampling platform(s);
- (vi) Safe access to sampling platform(s); and
- (vii) Utilities for sampling and testing equipment.

Each performance test shall consist of at least three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic mean of results of at least three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances beyond the owner or operator's control, compliance may, upon the Division's approval, be determined using the arithmetic mean of the results of the two other runs.

Nothing in this section shall abrogate the Division's authority to conduct its own performance test(s) if so warranted.

d. Affirmative Defense Provision for Excess Emissions during Malfunctions

Note that until such time as the U.S. EPA approves this provision into the Colorado State Implementation Plan (SIP), it shall be enforceable only by the State.

An affirmative defense to a claim of violation under these regulations is provided to owners and operators for civil penalty actions for excess emissions during periods of malfunction. To establish the affirmative defense and to be relieved of a civil penalty in any action to enforce an applicable requirement, the owner or operator of the facility must meet the notification requirements below in a timely manner and prove by a preponderance of evidence that:

- (i) The excess emissions were caused by a sudden, unavoidable breakdown of equipment, or a sudden, unavoidable failure of a process to operate in the normal or usual manner, beyond the reasonable control of the owner or operator;
- (ii) The excess emissions did not stem from any activity or event that could have reasonably been foreseen and avoided, or planned for, and could not have been avoided by better operation and maintenance practices;
- (iii) Repairs were made as expeditiously as possible when the applicable emission limitations were being exceeded;
- (iv) The amount and duration of the excess emissions (including any bypass) were minimized to the maximum extent practicable during periods of such emissions;
- (v) All reasonably possible steps were taken to minimize the impact of the excess emissions on ambient air quality;
- (vi) All emissions monitoring systems were kept in operation (if at all possible);
- (vii) The owner or operator's actions during the period of excess emissions were documented by properly signed, contemporaneous operating logs or other relevant evidence;
- (viii) The excess emissions were not part of a recurring pattern indicative of inadequate design, operation, or maintenance;
- (ix) At all times, the facility was operated in a manner consistent with good practices for minimizing emissions. This section is intended solely to be a factor in determining whether an affirmative defense is available to an owner or operator, and shall not constitute an additional applicable requirement; and
- (x) During the period of excess emissions, there were no exceedances of the relevant ambient air quality standards established in the Commissions' Regulations that could be attributed to the emitting source.

The owner or operator of the facility experiencing excess emissions during a malfunction shall notify the division verbally as soon as possible, but no later than noon of the Division's next working day, and shall submit written notification following the initial occurrence of the excess emissions by the end of the source's next reporting period. The notification shall address the criteria set forth above.

The Affirmative Defense Provision contained in this section shall not be available to claims for injunctive relief.

The Affirmative Defense Provision does not apply to failures to meet federally promulgated performance standards or emission limits, including, but not limited to, new source performance standards and national emission standards for hazardous air pollutants. The affirmative defense provision does not apply to state implementation plan (sip) limits or permit limits that have been set taking into account potential emissions during malfunctions, including, but not necessarily limited to, certain limits with 30-day or longer averaging times, limits that indicate they apply during malfunctions, and limits that indicate they apply at all times or without exception.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

#### e. Circumvention Clause

A person shall not build, erect, install, or use any article, machine, equipment, condition, or any contrivance, the use of which, without resulting in a reduction in the total release of air pollutants to the atmosphere, reduces or conceals an emission which would otherwise constitute a violation of this regulation. No person shall circumvent this regulation by using more openings than is considered normal practice by the industry or activity in question.

#### f. Compliance Certifications

For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in the Colorado State Implementation Plan, nothing in the Colorado State Implementation Plan shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. Evidence that has the effect of making any relevant standard or permit term more stringent shall not be credible for proving a violation of the standard or permit term.

When compliance or non-compliance is demonstrated by a test or procedure provided by permit or other applicable requirement, the owner or operator shall be presumed to be in compliance or non-compliance unless other relevant credible evidence overcomes that presumption.

g. Affirmative Defense Provision for Excess Emissions During Startup and Shutdown

An affirmative defense is provided to owners and operators for civil penalty actions for excess emissions during periods of startup and shutdown. To establish the affirmative defense and to be relieved of a civil penalty in any action to enforce an applicable requirement, the owner or operator of the facility must meet the notification requirements below in a timely manner and prove by a preponderance of the evidence that:

- (i) The periods of excess emissions that occurred during startup and shutdown were short and infrequent and could not have been prevented through careful planning and design;
- (ii) The excess emissions were not part of a recurring pattern indicative of inadequate design, operation or maintenance:
- (iii) If the excess emissions were caused by a bypass (an intentional diversion of control equipment), then the bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- (iv) The frequency and duration of operation in startup and shutdown periods were minimized to the maximum extent practicable;
- (v) All possible steps were taken to minimize the impact of excess emissions on ambient air quality;
- (vi) All emissions monitoring systems were kept in operation (if at all possible);
- (vii) The owner or operator's actions during the period of excess emissions were documented by properly signed, contemporaneous operating logs or other relevant evidence; and,
- (viii) At all times, the facility was operated in a manner consistent with good practices for minimizing emissions. This subparagraph is intended solely to be a factor in determining whether an affirmative defense is available to an owner or operator, and shall not constitute an additional applicable requirement.

The owner or operator of the facility experiencing excess emissions during startup and shutdown shall notify the Division verbally as soon as possible, but no later than two (2) hours after the start of the next working day, and shall submit written quarterly notification following the initial occurrence of the excess emissions. The notification shall address the criteria set forth above.

The Affirmative Defense Provision contained in this section shall not be available to claims for injunctive relief.

The Affirmative Defense Provision does not apply to State Implementation Plan provisions or other requirements that derive from new source performance standards or national emissions standards for hazardous air pollutants, or any other federally enforceable performance standard or emission limit with an averaging time greater than twenty-four hours. In addition, an affirmative defense cannot be used by a single source or small group of sources where the excess emissions have the potential to cause an exceedance of the ambient air quality standards or Prevention of Significant Deterioration (PSD) increments.

In making any determination whether a source established an affirmative defense, the Division shall consider the information within the notification required above and any other information the Division deems necessary, which may include, but is not limited to, physical inspection of the facility and review of documentation pertaining to the maintenance and operation of process and air pollution control equipment.

#### 4. Compliance Requirements

# Regulation No. 3, 5 CCR 1001-5, Part C, §§ III.C.9., V.C.11. & 16.d. and § 25-7-122.1(2), C.R.S.

- a. The permittee must comply with all conditions of the Operating Permit. Any permit noncompliance relating to federally-enforceable terms or conditions constitutes a violation of the federal act, as well as the state act and Regulation No. 3. Any permit noncompliance relating to state-only terms or conditions constitutes a violation of the state act and Regulation No. 3, shall be enforceable pursuant to state law, and shall not be enforceable by citizens under § 304 of the federal act. Any such violation of the federal act, the state act or regulations implementing either statute is grounds for enforcement action, for permit termination, revocation and reissuance or modification or for denial of a permit renewal application.
- b. It shall not be a defense for a permittee in an enforcement action or a consideration in favor of a permittee in a permit termination, revocation or modification action or action denying a permit renewal application that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- c. The permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of any request by the permittee for a permit modification, revocation and reissuance, or termination, or any notification of planned changes or anticipated noncompliance does not stay any permit condition, except as provided in §§ X. and XI. of Regulation No. 3, Part C.
- d. The permittee shall furnish to the Air Pollution Control Division, within a reasonable time as specified by the Division, any information that the Division may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Division copies of records required to be kept by the permittee, including information claimed to be confidential. Any information subject to a claim of confidentiality shall be specifically identified and submitted separately from information not subject to the claim.
- e. Any schedule for compliance for applicable requirements with which the source is not in compliance at the time of permit issuance shall be supplemental, and shall not sanction noncompliance with, the applicable requirements on which it is based.
- f. For any compliance schedule for applicable requirements with which the source is not in compliance at the time of permit issuance, the permittee shall submit, at least every 6 months unless a more frequent period is specified in the applicable requirement or by the Air Pollution Control Division, progress reports which contain the following:
  - (i) dates for achieving the activities, milestones, or compliance required in the schedule for compliance, and dates when such activities, milestones, or compliance were achieved; and
  - (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

g. The permittee shall not knowingly falsify, tamper with, or render inaccurate any monitoring device or method required to be maintained or followed under the terms and conditions of the Operating Permit.

#### 5. Emergency Provisions

#### Regulation No. 3, 5 CCR 1001-5, Part C, § VII.

An emergency means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed the technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. "Emergency" does not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error. An emergency constitutes an affirmative defense to an enforcement action brought for noncompliance with a technology-based emission limitation if the permittee demonstrates, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- a. an emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. the permitted facility was at the time being properly operated;
- c. during the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- d. the permittee submitted oral notice of the emergency to the Air Pollution Control Division no later than noon of the next working day following the emergency, and followed by written notice within one month of the time when emissions limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

This emergency provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

#### 6. Emission Standards for Asbestos

#### Regulation No. 8, 5 CCR 1001-10, Part B

The permittee shall not conduct any asbestos abatement activities except in accordance with the provisions of Regulation No. 8, Part B, "emission standards for asbestos."

#### 7. Emissions Trading, Marketable Permits, Economic Incentives

### Regulation No. 3, 5 CCR 1001-5, Part C, § V.C.13.

No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are specifically provided for in the permit.

#### 8. Fee Payment

#### C.R.S. §§ 25-7-114.1(6) and 25-7-114.7

- a. The permittee shall pay an annual emissions fee in accordance with the provisions of C.R.S. § 25-7-114.7. A 1% per month late payment fee shall be assessed against any invoice amounts not paid in full on the 91st day after the date of invoice, unless a permittee has filed a timely protest to the invoice amount.
- b. The permittee shall pay a permit processing fee in accordance with the provisions of C.R.S. § 25-7-114.7. If the Division estimates that processing of the permit will take more than 30 hours, it will notify the permittee of its estimate of what the actual charges may be prior to commencing any work exceeding the 30 hour limit.

c. The permittee shall pay an APEN fee in accordance with the provisions of C.R.S. § 25-7-114.1(6) for each APEN or revised APEN filed.

#### 9. Fugitive Particulate Emissions

#### Regulation No. 1, 5 CCR 1001-3, § III.D.1.

The permittee shall employ such control measures and operating procedures as are necessary to minimize fugitive particulate emissions into the atmosphere, in accordance with the provisions of Regulation No. 1, § III.D.1.

#### 10. Inspection and Entry

#### Regulation No. 3, 5 CCR 1001-5, Part C, § V.C.16.b.

Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Air Pollution Control Division, or any authorized representative, to perform the following:

- a. enter upon the permittee's premises where an Operating Permit source is located, or emissions-related activity is conducted, or where records must be kept under the terms of the permit;
- b. have access to, and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- c. inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the Operating Permit;
- d. sample or monitor at reasonable times, for the purposes of assuring compliance with the Operating Permit or applicable requirements, any substances or parameters.

#### 11. Minor Permit Modifications

#### Regulation No. 3, 5 CCR 1001-5, Part C, §§ X. & XI.

The permittee shall submit an application for a minor permit modification before making the change requested in the application. The permit shield shall not extend to minor permit modifications.

#### 12. New Source Review

#### Regulation No. 3, 5 CCR 1001-5, Part B

The permittee shall not commence construction or modification of a source required to be reviewed under the New Source Review provisions of Regulation No. 3, Part B, without first receiving a construction permit.

#### 13. No Property Rights Conveyed

#### Regulation No. 3, 5 CCR 1001-5, Part C, § V.C.11.d.

This permit does not convey any property rights of any sort, or any exclusive privilege.

#### 14. Odor

#### Regulation No. 2, 5 CCR 1001-4, Part A

As a matter of state law only, the permittee shall comply with the provisions of Regulation No. 2 concerning odorous emissions.

#### 15. Off-Permit Changes to the Source

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

### Regulation No. 3, 5 CCR 1001-5, Part C, § XII.B.

The permittee shall record any off-permit change to the source that causes the emissions of a regulated pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from the change, including any other data necessary to show compliance with applicable ambient air quality standards. The permittee shall provide contemporaneous notification to the Air Pollution Control Division and to the Environmental Protection Agency at the addresses listed in Appendix D of this Permit . The permit shield shall not apply to any off-permit change.

#### 16. Opacity

#### Regulation No. 1, 5 CCR 1001-3, §§ I., II.

The permittee shall comply with the opacity emissions limitation set forth in Regulation No. 1, §§ I.-II.

### 17. Open Burning

#### Regulation No. 9, 5 CCR 1001-11

The permittee shall obtain a permit from the Division for any regulated open burning activities in accordance with provisions of Regulation No. 9.

### 18. Ozone Depleting Compounds

#### Regulation No. 15, 5 CCR 1001-19

The permittee shall comply with the provisions of Regulation No. 15 concerning emissions of ozone depleting compounds. Sections I., II.C., II.D., III. IV., and V. of Regulation No. 15 shall be enforced as a matter of state law only.

#### 19. Permit Expiration and Renewal

#### Regulation No. 3, 5 CCR 1001-5, Part C, §§ III.B.6., IV.C., V.C.2.

- a. The permit term shall be five (5) years. The permit shall expire at the end of its term. Permit expiration terminates the permittee's right to operate unless a timely and complete renewal application is submitted.
- b. Applications for renewal shall be submitted at least twelve months, but not more than 18 months, prior to the expiration of the Operating Permit. An application for permit renewal may address only those portions of the permit that require revision, supplementing, or deletion, incorporating the remaining permit terms by reference from the previous permit. A copy of any materials incorporated by reference must be included with the application.

#### 20. Portable Sources

#### Regulation No. 3, 5 CCR 1001-5, Part C, § II.D.

Portable Source permittees shall notify the Air Pollution Control Division at least 10 days in advance of each change in location.

# 21. Prompt Deviation Reporting

#### Regulation No. 3, 5 CCR 1001-5, Part C, § V.C.7.b.

The permittee shall promptly report any deviation from permit requirements, including those attributable to malfunction conditions as defined in the permit, the probable cause of such deviations, and any corrective actions or preventive measures taken.

"Prompt" is defined as follows:

a. Any definition of "prompt" or a specific timeframe for reporting deviations provided in an underlying applicable

requirement as identified in this permit; or

- b. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations will be submitted based on the following schedule:
  - i. For emissions of a hazardous air pollutant or a toxic air pollutant (as identified in the applicable regulation) that continue for more than an hour in excess of permit requirements, the report shall be made within 24 hours of the occurrence:
  - ii. For emissions of any regulated air pollutant, excluding a hazardous air pollutant or a toxic air pollutant that continue for more than two hours in excess of permit requirements, the report shall be made within 48 hours; and
  - iii. For all other deviations from permit requirements, the report shall be submitted every six (6) months, except as otherwise specified by the Division in the permit in accordance with paragraph 22.d. below.
- c. If any of the conditions in paragraphs b.i or b.ii above are met, the source shall notify the Division by telephone (303-692-3155) or facsimile (303-782-0278) based on the timetables listed above. [Explanatory note: Notification by telephone or facsimile must specify that this notification is a deviation report for an Operating Permit.] A written notice, certified consistent with General Condition 2.a. above (Certification Requirements), shall be submitted within 10 working days of the occurrence. All deviations reported under this section shall also be identified in the 6-month report required above.

"Prompt reporting" does not constitute an exception to the requirements of "Emergency Provisions" for the purpose of avoiding enforcement actions.

# 22. Record Keeping and Reporting Requirements

#### Regulation No. 3. 5 CCR 1001-5. Part A. § II.: Part C. §§ V.C.6., V.C.7.

- a. Unless otherwise provided in the source specific conditions of this Operating Permit, the permittee shall maintain compliance monitoring records that include the following information:
  - (i) date, place as defined in the Operating Permit, and time of sampling or measurements;
  - (ii) date(s) on which analyses were performed;
  - (iii) the company or entity that performed the analysis;
  - (iv) the analytical techniques or methods used;
  - (v) the results of such analysis; and
  - (vi) the operating conditions at the time of sampling or measurement.
- b. The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of the monitoring sample, measurement, report or application. Support information, for this purpose, includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the Operating Permit. With prior approval of the Air Pollution Control Division, the permittee may maintain any of the above records in a computerized form.
- c. Permittees must retain records of all required monitoring data and support information for the most recent twelve (12) month period, as well as compliance certifications for the past five (5) years on-site at all times. A permittee shall make available for the Air Pollution Control Division's review all other records of required monitoring data and support information required to be retained by the permittee upon 48 hours advance notice by the Division.

- d. The permittee shall submit to the Air Pollution Control Division all reports of any required monitoring at least every six (6) months, unless an applicable requirement, the compliance assurance monitoring rule, or the Division requires submission on a more frequent basis. All instances of deviations from any permit requirements must be clearly identified in such reports.
- e. The permittee shall file an Air Pollutant Emissions Notice ("APEN") prior to constructing, modifying, or altering any facility, process, activity which constitutes a stationary source from which air pollutants are or are to be emitted, unless such source is exempt from the APEN filing requirements of Regulation No. 3, Part A, § II.D. A revised APEN shall be filed annually whenever a significant change in emissions, as defined in Regulation No. 3, Part A, § II.C.2., occurs; whenever there is a change in owner or operator of any facility, process, or activity; whenever new control equipment is installed; whenever a different type of control equipment replaces an existing type of control equipment; whenever a permit limitation must be modified; or before the APEN expires. An APEN is valid for a period of five years. The five-year period recommences when a revised APEN is received by the Air Pollution Control Division. Revised APENs shall be submitted no later than 30 days before the five-year term expires. Permittees submitting revised APENs to inform the Division of a change in actual emission rates must do so by April 30 of the following year. Where a permit revision is required, the revised APEN must be filed along with a request for permit revision. APENs for changes in control equipment must be submitted before the change occurs. Annual fees are based on the most recent APEN on file with the Division.

#### 23. Reopenings for Cause

### Regulation No. 3, 5 CCR 1001-5, Part C, § XIII.

- a. The Air Pollution Control Division shall reopen, revise, and reissue Operating Permits; permit reopenings and reissuance shall be processed using the procedures set forth in Regulation No. 3, Part C, § III., except that proceedings to reopen and reissue permits affect only those parts of the permit for which cause to reopen exists.
- b. The Division shall reopen a permit whenever additional applicable requirements become applicable to a major source with a remaining permit term of three or more years, unless the effective date of the requirements is later than the date on which the permit expires, or unless a general permit is obtained to address the new requirements; whenever additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program; whenever the Division determines the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit; or whenever the Division determines that the permit must be revised or revoked to assure compliance with an applicable requirement.
- c. The Division shall provide 30 days' advance notice to the permittee of its intent to reopen the permit, except that a shorter notice may be provided in the case of an emergency.
- d. The permit shield shall extend to those parts of the permit that have been changed pursuant to the reopening and reissuance procedure.

#### **24.** Section 502(b)(10) Changes

### Regulation No. 3, 5 CCR 1001-5, Part C, § XII.A.

The permittee shall provide a minimum 7-day advance notification to the Air Pollution Control Division and to the Environmental Protection Agency at the addresses listed in Appendix D of this Permit. The permittee shall attach a copy of each such notice given to its Operating Permit.

#### 25. Severability Clause

#### Regulation No. 3, 5 CCR 1001-5, Part C, § V.C.10.

In the event of a challenge to any portion of the permit, all emissions limits, specific and general conditions, monitoring, record keeping and reporting requirements of the permit, except those being challenged, remain valid and enforceable.

### 26. Significant Permit Modifications

#### Regulation No. 3, 5 CCR 1001-5, Part C, §III.B.2.

The permittee shall not make a significant modification required to be reviewed under Regulation No. 3, Part B ("Construction Permit" requirements) without first receiving a construction permit. The permittee shall submit a complete Operating Permit application or application for an Operating Permit revision for any new or modified source within twelve months of commencing operation, to the address listed in Item 1 in Appendix D of this permit. If the permittee chooses to use the "Combined Construction/Operating Permit" application procedures of Regulation No. 3, Part C, then the Operating Permit must be received prior to commencing construction of the new or modified source.

# 27. Special Provisions Concerning the Acid Rain Program

# Regulation No. 3, 5 CCR 1001-5, Part C, §§ V.C.1.b. & 8

- a. Where an applicable requirement of the federal act is more stringent than an applicable requirement of regulations promulgated under Title IV of the federal act, 40 Code of Federal Regulations (CFR) Part 72, both provisions shall be incorporated into the permit and shall be federally enforceable.
- b. Emissions exceeding any allowances that the source lawfully holds under Title IV of the federal act or the regulations promulgated thereunder, 40 CFR Part 72, are expressly prohibited.

### 28. Transfer or Assignment of Ownership

#### Regulation No. 3, 5 CCR 1001-5, Part C, § II.C.

No transfer or assignment of ownership of the Operating Permit source will be effective unless the prospective owner or operator applies to the Air Pollution Control Division on Division-supplied Administrative Permit Amendment forms, for reissuance of the existing Operating Permit. No administrative permit shall be complete until a written agreement containing a specific date for transfer of permit, responsibility, coverage, and liability between the permittee and the prospective owner or operator has been submitted to the Division.

### 29. Volatile Organic Compounds

# Regulation No. 7, 5 CCR 1001-9, §§ III & V.

a. For sources located in an ozone non-attainment area or the Denver Metro Attainment Maintenance Area, all storage tank gauging devices, anti-rotation devices, accesses, seals, hatches, roof drainage systems, support structures, and pressure relief valves shall be maintained and operated to prevent detectable vapor loss except when opened, actuated, or used for necessary and proper activities (e.g. maintenance). Such opening, actuation, or use shall be limited so as to minimize vapor loss.

Detectable vapor loss shall be determined visually, by touch, by presence of odor, or using a portable hydrocarbon analyzer. When an analyzer is used, detectable vapor loss means a VOC concentration exceeding 10,000 ppm. Testing shall be conducted as in Regulation No. 7, Section VIII.C.3.

Except when otherwise provided by Regulation No. 7, all volatile organic compounds, excluding petroleum liquids, transferred to any tank, container, or vehicle compartment with a capacity exceeding 212 liters (56 gallons), shall be transferred using submerged or bottom filling equipment. For top loading, the fill tube shall reach within six inches of the bottom of the tank compartment. For bottom-fill operations, the inlet shall be flush with the tank bottom.

- b. The permittee shall not dispose of volatile organic compounds by evaporation or spillage unless Reasonably Available Control Technology (RACT) is utilized.
- c. No owner or operator of a bulk gasoline terminal, bulk gasoline plant, or gasoline dispensing facility as defined in Colorado Regulation No. 7, Section VI, shall permit gasoline to be intentionally spilled, discarded in sewers, stored in open containers, or disposed of in any other manner that would result in evaporation.

#### **30. Wood Stoves and Wood burning Appliances**

Regulation No. 4, 5 CCR 1001-6

The permittee shall comply with the provisions of Regulation No. 4 concerning the advertisement, sale, installation, and use of wood stoves and wood burning appliances.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# **OPERATING PERMIT APPENDICES**

- A INSPECTION INFORMATION
- **B MONITORING AND PERMIT DEVIATION REPORT**
- C COMPLIANCE CERTIFICATION REPORT
- **D-NOTIFICATION ADDRESSES**
- **E-PERMIT ACRONYMS**
- F PERMIT MODIFICATIONS

# \*DISCLAIMER:

None of the information found in these Appendices shall be considered to be State or Federally enforceable, except as otherwise provided in the permit, and is presented to assist the source, permitting authority, inspectors, and citizens.

# **APPENDIX A - Inspection Information**

#### **Directions to Plant**:

Peterson Air Force Base is located in the South East portion of Colorado Springs. It is East of Powers Boulevard and immediately North of the Colorado Springs Municipal airport.

# **Safety Equipment Required:**

Hearing protection is required for flight line activities.

# **Facility Plot Plan:**

Figure 1 (following page) shows the plot plan as submitted on February 23, 1996, with the source's Title V Operating Permit Application.

# **List of Insignificant Activities**:

The following list of insignificant activities was provided by the source to assist in the understanding of the facility layout. Since there is no requirement to update such a list, activities may have changed since the last filing.

Specific insignificant activities and/or sources of emissions as submitted in the application are as follows:

Source Type	Description/Quantity of Sources
Storage Tanks	94 gasoline, diesel, fuel oil and waste oil tanks.
Boilers, Furnaces, Heaters	26 hot water boilers, treatment
	10 steam boilers, treatment
	994 heat boilers & furnaces
	24 hot water boilers
Cooling Towers	3 cooling towers
Generators	39 generators operating less than 250 hours per year
Fuel Loading	Aviation fuel loading into tanker trucks
	JP-8 loading into tanker trucks
Fugitive Emissions	Misc. chemical usage in shops
	Ventilation of emissions from vehicle maintenance
	Fire control training
	Jet engine testing
Ground Surface Disturbance	Construction activities less than 25 contiguous acres
	which do not exceed 6 months
Miscellaneous Engines	Landscaping and site housekeeping devices less than
	or equal to 10 hp
Chemical Storage	Chemical storage less than 5,000 gallons

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

### Appendix B **Reporting Requirements and Definitions** with codes ver 2/20/07

Please note that, pursuant to 113(c)(2) of the federal Clean Air Act, any person who knowingly:

- (A) makes any false material statement, representation, or certification in, or omits material information from, or knowingly alters, conceals, or fails to file or maintain any notice, application, record, report, plan, or other document required pursuant to the Act to be either filed or maintained (whether with respect to the requirements imposed by the Administrator or by a State);
- (B) fails to notify or report as required under the Act; or
- falsifies, tampers with, renders inaccurate, or fails to install any monitoring device or method required to (C) be maintained or followed under the Act shall, upon conviction, be punished by a fine pursuant to title 18 of the United States Code, or by imprisonment for not more than 2 years, or both. If a conviction of any person under this paragraph is for a violation committed after a first conviction of such person under this paragraph, the maximum punishment shall be doubled with respect to both the fine and imprisonment.

The permittee must comply with all conditions of this operating permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

The Part 70 Operating Permit program requires three types of reports to be filed for all permits. All required reports must be certified by a responsible official.

#### **Report #1: Monitoring Deviation Report** (due at least every six months)

For purposes of this operating permit, the Division is requiring that the monitoring reports are due every six months unless otherwise noted in the permit. All instances of deviations from permit monitoring requirements must be clearly identified in such reports.

For purposes of this operating permit, monitoring means any condition determined by observation, by data from any monitoring protocol, or by any other monitoring which is required by the permit as well as the recordkeeping associated with that monitoring. This would include, for example, fuel use or process rate monitoring, fuel analyses, and operational or control device parameter monitoring.

# **Report #2: Permit Deviation Report (must be reported "promptly")**

In addition to the monitoring requirements set forth in the permits as discussed above, each and every requirement of the permit is subject to deviation reporting. The reports must address deviations from permit requirements, including those attributable to malfunctions as defined in this Appendix, the probable cause of such deviations, and any corrective actions or preventive measures taken. All deviations from any term or condition of the permit are required to be summarized or referenced in the annual compliance certification.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

For purposes of this operating permit, "malfunction" shall refer to both emergency conditions and malfunctions. Additional discussion on these conditions is provided later in this Appendix.

For purposes of this operating permit, the Division is requiring that the permit deviation reports are due as set forth in General Condition 21. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. For example, quarterly Excess Emission Reports required by an NSPS or Regulation No. 1, Section IV.

In addition to the monitoring deviations discussed above, included in the meaning of deviation for the purposes of this operating permit are any of the following:

- (1) A situation where emissions exceed an emission limitation or standard contained in the permit;
- (2) A situation where process or control device parameter values demonstrate that an emission limitation or standard contained in the permit has not been met;
- (3) A situation in which observations or data collected demonstrates noncompliance with an emission limitation or standard or any work practice or operating condition required by the permit; or,
- (4) A situation in which an excursion or exceedance as defined in 40CFR Part 64 (the Compliance Assurance Monitoring (CAM) Rule) has occurred. (only if the emission point is subject to CAM)

For reporting purposes, the Division has combined the Monitoring Deviation Report with the Permit Deviation Report. All deviations shall be reported using the following codes:

1 = Standard: When the requirement is an emission limit or standard 2 = Process: When the requirement is a production/process limit

**3 = Monitor:** When the requirement is monitoring **4 = Test:** When the requirement is testing

5 = Maintenance: When required maintenance is not performed
 6 = Record: When the requirement is recordkeeping
 7 = Report: When the requirement is reporting

8 = CAM: A situation in which an excursion or exceedance as defined in 40CFR Part 64 (the

Compliance Assurance Monitoring (CAM) Rule) has occurred.

**9 = Other:** When the deviation is not covered by any of the above categories

### **Report #3: Compliance Certification (annually, as defined in the permit)**

Submission of compliance certifications with terms and conditions in the permit, including emission limitations, standards, or work practices, is required not less than annually.

Compliance Certifications are intended to state the compliance status of each requirement of the permit over the certification period. They must be based, at a minimum, on the testing and monitoring methods specified in the permit that were conducted during the relevant time period. In addition, if the owner or operator knows of other material information (i.e. information beyond required monitoring that has been specifically assessed in relation

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

to how the information potentially affects compliance status), that information must be identified and addressed in the compliance certification. The compliance certification must include the following:

- The identification of each term or condition of the permit that is the basis of the certification;
- Whether or not the method(s) used by the owner or operator for determining the compliance status with each permit term and condition during the certification period was the method(s) specified in the permit. Such methods and other means shall include, at a minimum, the methods and means required in the permit. If necessary, the owner or operator also shall identify any other material information that must be included in the certification to comply with section 113(c)(2) of the Federal Clean Air Act, which prohibits knowingly making a false certification or omitting material information;
- The status of compliance with the terms and conditions of the permit, and whether compliance was continuous or intermittent. The certification shall identify each deviation and take it into account in the compliance certification. Note that not all deviations are considered violations.<sup>1</sup>
- Such other facts as the Division may require, consistent with the applicable requirements to which the source is subject, to determine the compliance status of the source.

The Certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR Part 64 (the Compliance Assurance Monitoring (CAM) Rule) has occurred. (only for emission points subject to CAM)

Note the requirement that the certification shall identify each deviation and take it into account in the compliance certification. Previously submitted deviation reports, including the deviation report submitted at the time of the annual certification, may be referenced in the compliance certification.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

<sup>1</sup> 

<sup>&</sup>lt;sup>1</sup> For example, given the various emissions limitations and monitoring requirements to which a source may be subject, a deviation from one requirement may not be a deviation under another requirement which recognizes an exception and/or special circumstances relating to that same event.

# Startup, Shutdown, Malfunctions and Emergencies,

Understanding the application of Startup, Shutdown, Malfunctions and Emergency Provisions, is very important in both the deviation reports and the annual compliance certifications.

### Startup, Shutdown, and Malfunctions

Please note that exceedances of some New Source Performance Standards (NSPS) and Maximum Achievable Control Technology (MACT) standards that occur during Startup, Shutdown or Malfunctions may not be considered to be non-compliance since emission limits or standards often do not apply unless specifically stated in the NSPS. Such exceedances must, however, be reported as excess emissions per the NSPS/MACT rules and would still be noted in the deviation report. In regard to compliance certifications, the permittee should be confident of the information related to those deviations when making compliance determinations since they are subject to Division review. The concepts of Startup, Shutdown and Malfunctions also exist for Best Available Control Technology (BACT) sources, but are not applied in the same fashion as for NSPS and MACT sources.

### **Emergency Provisions**

Under the Emergency provisions of Part 70 certain operational conditions may act as an affirmative defense against enforcement action if they are properly reported.

### **DEFINITIONS**

**Malfunction** (NSPS) means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

**Malfunction** (SIP) means any sudden and unavoidable failure of air pollution control equipment or process equipment or unintended failure of a process to operate in a normal or usual manner. Failures that are primarily caused by poor maintenance, careless operation, or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.

**Emergency** means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

# **APPENDIX B: Monitoring and Permit Deviation Report - Part I**

- 1. Following is the **required** format for the Monitoring and Permit Deviation report to be submitted to the Division as set forth in General Condition 21. The Table below must be completed for all equipment or processes for which specific Operating Permit terms exist.
- 2. Part II of this Appendix B shows the format and information the Division will require for describing periods of monitoring and permit deviations, or malfunction or emergency conditions as indicated in the Table below. One Part II Form must be completed for each Deviation. Previously submitted reports (e.g. EER's or malfunctions) may be referenced and the form need not be filled out in its entirety.

FACILITY NAME: Peterson AFB	
OPERATING PERMIT NO: 950PEP147	
REPORTING PERIOD:	(see first page of the permit for specific reporting period and
dates)	

Operating Permit		Deviation During I		Deviation Code 2	Malfunction Condition During	Reported
Unit ID	Unit Description	YES	NO		YES	NO
029	Bldg. 1360 gasoline service station.					
030	Bldg. 1700 gasoline service station.					
036	Bldg. 920 Caterpillar SR-4 Emergency generator.					
045	Base-wide HAP emissions.					
046	Bldg. 218 – 850 hp Emergency Generator: Cummins, diesel fueled					
047	Bldg. 2 – Three 2020 hp Emergency Generators. Cummins, diesel fueled.					
050	Bldg. 600 – Two document disintegrators.					
053	Bldg. 1844 – 2680hp Emergency Generator, Cummins, diesel fueled.					
057	Bldg. 1840 – 2000 kW Emergency Generator, Cummins, diesel fueled.					
060	Bldg. 2 – 2600 hp Emergency Generator, Cummins, diesel fueled.					
061	Bldg. 2 – 2600 hp Emergency Generator, Cummins, diesel fueled.					
064	Bldg. 3 – 2220 hp Emergency Generator, Cummins, diesel fueled.					
065	Bldg. 216 – Paint Booth.					
066	Bldg. 504 – 99 hp Emergency Generator, Cummins, diesel fueled.					

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

Operating Permit		Deviation During Po		Deviation Code	Malfunction Condition During	Reported
Unit ID	Unit Description	YES	NO		YES	NO
067	Bldg. 1334 – 364 hp Emergency Generator, Cummins, diesel fueled.					
N/A	Bldg. 1232 – Two 10,000 gallon gasoline tanks.					
N/A	Bldg. 200 – Two 500 gallon gasoline tanks.					
General Conditions						
Insignificant Activities						

<sup>&</sup>lt;sup>1</sup> See previous discussion regarding what is considered to be a deviation. Determination of whether or not a deviation has occurred shall be based on a reasonable inquiry using readily available information.

**1 = Standard:** When the requirement is an emission limit or standard When the requirement is a production/process limit 2 = Process:

**3 = Monitor:** When the requirement is monitoring When the requirement is testing **4** = Test:

When required maintenance is not performed **5** = Maintenance: When the requirement is recordkeeping 6 = Record:When the requirement is reporting **7 = Report:** 

A situation in which an excursion or exceedance as defined in 40CFR Part 64 (the 8 = CAM:

Compliance Assurance Monitoring (CAM) Rule) has occurred.

When the deviation is not covered by any of the above categories **9 = Other:** 

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

<sup>&</sup>lt;sup>2</sup> Use the following entries, as appropriate

# **APPENDIX B: Monitoring and Permit Deviation Report - Part II**

FACILITY NAME: Peterson AFB OPERATING PERMIT NO: 950PEP147 REPORTING PERIOD:			
Is the deviation being claimed as an:	Emergency	_ Malfunction_	N/A
(For NSPS/MACT) Did the deviation occur during:	Startup	Shutdown	Malfunction
	Normal Operation		
OPERATING PERMIT UNIT IDENTIFICATION:			
Operating Permit Condition Number Citation			
Explanation of Period of Deviation			
Duration (start/stop date & time)			
Action Taken to Correct the Problem			
Measures Taken to Prevent a Reoccurrence of the Pr	roblem		
Dates of Malfunctions/Emergencies Reported (if app	olicable)		
	<del> </del>		
Deviation Code	Division Code QA:		

SEE EXAMPLE ON THE NEXT PAGE

Acme Corp.

FACILITY NAME:

# **EXAMPLE**

Emergency	_ Malfunction _	XX	N/A
Startup Normal Operation	Shutdown	Malfunct	ion
l - Unit XXX			
<u>blem</u>			
icable)			
Division Code QA:			
	Startup Normal Operation  I - Unit XXX  blem  licable)	Startup Shutdown Normal Operation  I - Unit XXX	blem licable)

# **APPENDIX B: Monitoring and Permit Deviation Report - Part III**

# REPORT CERTIFICATION

FACILITY IDENTIFICATION NUI	IBER: 0410016	
PERMIT NUMBER: 950PEP147		
REPORTING PERIOD:	(see first page of the permit for specific reporting per	riod and dates)
	-Annual Deviation Reports must be certified by a respons 3, Part A, Section I.B.38. This signed certification documentated.	
STATEMENT OF COMPLETEN	SS	
	eeing submitted in its entirety and, based on informaticertify that the statements and information contained in	
	tes state that any person who knowingly, as defined in Sunaterial statement, representation, or certification in thi	
guilty of a misdemeanor and may	be punished in accordance with the provisions of Sub	
guilty of a misdemeanor and may	be punished in accordance with the provisions of Sub	
guilty of a misdemeanor and may 122.1, C.R.S.	be punished in accordance with the provisions of Subsection of Subsectio	o-Section 25-7

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009

### **APPENDIX C**

### **Required Format for Annual Compliance Certification Reports**

Following is the format for the Compliance Certification report to be submitted to the Division and the U.S. EPA annually based on the effective date of the permit. The Table below must be completed for all equipment or processes for which specific Operating Permit terms exist.

FACILITY NAME: Peterson AFB

OPERATING PERMIT NO: 950PEP147

REPORTING PERIOD:

#### I Facility Status

During the entire reporting period, this source was in compliance with <b>ALL</b> terms and conditions.	itions contained
in the Permit, each term and condition of which is identified and included by this reference.	The method(s)
used to determine compliance is/are the method(s) specified in the Permit.	

With the possible exception of the deviations identified in the table below, this source was in compliance with all terms and conditions contained in the Permit, each term and condition of which is identified and included by this reference, during the entire reporting period. The method used to determine compliance for each term and condition is the method specified in the Permit, unless otherwise indicated and described in the deviation report(s). Note that not all deviations are considered violations.

Operating Permit Unit ID	Unit Description	Deviations Reported <sup>1</sup>		Deviations		Monit Metho Perm	d per	Was compliand interm	ce continuous or ittent? <sup>3</sup>
110		Previous	Current	YES	NO	Continuous	Intermittent		
029	Bldg. 1360 gasoline service station.								
030	Bldg. 1700 gasoline service station.								
036	Bldg. 920 Caterpillar SR-4 Emergency generator.								
045	Base-wide HAP emissions.								
046	Bldg. 218 – 850 hp Emergency Generator: Cummins, diesel fueled								
047	Bldg. 2 – Three 2020 hp Emergency Generators. Cummins, diesel fueled.								
050	Bldg. 600 – Two document disintegrators.								

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

Operating Permit Unit ID	Unit Description		Deviations Reported <sup>1</sup>		oring od per nit? <sup>2</sup>	Was compliand interm	ce continuous or ittent? <sup>3</sup>
ID .		Previous	Current	YES	NO	Continuous	Intermittent
053	Bldg. 1844 – 2680hp Emergency Generator, Cummins, diesel fueled.						
057	Bldg. 1840 – 2000 kW Emergency Generator, Cummins, diesel fueled.						
060	Bldg. 2 – 2600 hp Emergency Generator, Cummins, diesel fueled.						
061	Bldg. 2 – 2600 hp Emergency Generator, Cummins, diesel fueled.						
064	Bldg. 3 – 2220 hp Emergency Generator, Cummins, diesel fueled.						
065	Bldg. 216 – Paint Booth.						
066	Bldg. 504 – 99 hp Emergency Generator, Cummins, diesel fueled.						
067	Bldg. 1334 – 364 hp Emergency Generator, Cummins, diesel fueled.						
N/A	Bldg. 1232 – Two 10,000 gallon gasoline tanks.						
N/A	Bldg. 200 – Two 500 gallon gasoline tanks.						
General Conditions							
Insignificant Activities <sup>4</sup>							

<sup>&</sup>lt;sup>1</sup> If deviations were noted in a previous deviation report, put an "X" under "previous". If deviations were noted in the current deviation report (i.e. for the last six months of the annual reporting period), put an "X" under "current". Mark both columns if both apply.

<sup>&</sup>lt;sup>2</sup> Note whether the method(s) used to determine the compliance status with each term and condition was the method(s) specified in the permit. If it was not, mark "no" and attach additional information/explanation.

<sup>&</sup>lt;sup>3</sup> Note whether the compliance status with of each term and condition provided was continuous or intermittent. "Intermittent Compliance" can mean either that noncompliance has occurred or that the owner or operator has data sufficient to certify compliance only on an intermittent basis. Certification of intermittent compliance therefore does not necessarily mean that any noncompliance has occurred.

Operating Permit Number: 95OPEP147

#### NOTE:

The Periodic Monitoring requirements of the Operating Permit program rule are intended to provide assurance that even in the absence of a continuous system of monitoring the Title V source can demonstrate whether it has operated in continuous compliance for the duration of the reporting period. Therefore, if a source 1) conducts all of the monitoring and recordkeeping required in its permit, even if such activities are done periodically and not continuously, and if 2) such monitoring and recordkeeping does not indicate non-compliance, and if 3) the Responsible Official is not aware of any credible evidence that indicates non-compliance, then the Responsible Official can certify that the emission point(s) in question were in continuous compliance during the applicable time period.

<sup>4</sup> Compliance status for these sources shall be based on a reasonable inquiry using readily available information. Status for Accidental Release Prevention Program: II. This facility \_\_\_\_\_ is subject \_\_\_\_\_ is not subject to the provisions of the Accidental Release Prevention Program (Section 112(r) of the Federal Clean Air Act) A. If subject: The facility \_\_\_\_\_ is \_\_\_\_ is not in compliance with all the В. requirements of section 112(r). A Risk Management Plan \_\_\_\_\_ will be \_\_\_\_\_ has been submitted to the appropriate authority and/or the designated central location by the required date. 1. III. Certification All information for the Annual Compliance Certification must be certified by a responsible official as defined in Colorado Regulation No. 3, Part A, Section I.B.38. This signed certification document must be packaged with the documents being submitted. I have reviewed this certification in its entirety and, based on information and belief formed after reasonable inquiry, I certify that the statements and information contained in this certification are true, accurate and complete. Please note that the Colorado Statutes state that any person who knowingly, as defined in § 18-1-501(6), C.R.S., makes any false material statement, representation, or certification in this document is guilty of a misdemeanor and may be punished in accordance with the provisions of § 25-7 122.1, C.R.S. Printed or Typed Name Title Signature Date Signed NOTE: All compliance certifications shall be submitted to the Air Pollution Control Division and to the Environmental Protection Agency at the addresses listed in Appendix D of this Permit.

> First Issued: March 3, 1998 Renewed: January 1, 2009

### APPENDIX D

### **Notification Addresses**

### 1. **Air Pollution Control Division**

Colorado Department of Public Health and Environment Air Pollution Control Division Operating Permits Unit APCD-SS-B1 4300 Cherry Creek Drive S. Denver, CO 80246-1530

ATTN: Jim King

### 2. United States Environmental Protection Agency

### **Compliance Notifications:**

Office of Enforcement, Compliance and Environmental Justice Mail Code 8ENF-T U.S. Environmental Protection Agency, Region VIII 1595 Wynkoop Street Denver, CO 80202-1129

### Permit Modifications, Off Permit Changes:

Office of Partnerships and Regulatory Assistance Air and Radiation Programs, 8P-AR U.S. Environmental Protection Agency, Region VIII 1595 Wynkoop Street Denver, CO 80202-1129

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

### APPENDIX E

### **Permit Acronyms**

## Listed Alphabetically:

AIRS -	Aerometric Information Retrieval System
AP-42 -	EPA Document Compiling Air Pollutant Emission Factors
APEN -	Air Pollution Emission Notice (State of Colorado)
APCD -	Air Pollution Control Division (State of Colorado)
ASTM -	American Society for Testing and Materials
BACT -	Best Available Control Technology
BTU -	British Thermal Unit
CAA -	Clean Air Act (CAAA = Clean Air Act Amendments)
CCR -	Colorado Code of Regulations
CEM -	Continuous Emissions Monitor
CF -	Cubic Feet (SCF = Standard Cubic Feet)
CFR -	Code of Federal Regulations
CO -	Carbon Monoxide
COM -	Continuous Opacity Monitor
CRS -	Colorado Revised Statute
EF -	Emission Factor
EPA -	Environmental Protection Agency
FI -	Fuel Input Rate in Lbs/mmBtu
FR -	Federal Register
G -	Grams
Gal -	Gallon
GPM -	Gallons per Minute
HAPs -	Hazardous Air Pollutants
IID	II and an avvian

HP-Horsepower

Horsepower Hour (G/HP-HR = Grams per Horsepower Hour) HP-HR -

LAER -Lowest Achievable Emission Rate

Pounds LBS -M -Thousand MM -Million

MMscf-Million Standard Cubic Feet

Million Standard Cubic Feet per Day MMscfd -

N/A or NA -Not Applicable Nitrogen Oxides NOx -

NESHAP -National Emission Standards for Hazardous Air Pollutants

NSPS -New Source Performance Standards P -Process Weight Rate in Tons/Hr

PE -**Particulate Emissions** PM -Particulate Matter

Particulate Matter Under 10 Microns  $PM_{10}$  -

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998

PSD -	Prevention	of Significant	Deterioration
100		or orginitionit	Deterroration

PTE - Potential To Emit

RACT - Reasonably Available Control Technology

SCC - Source Classification Code

SCF - Standard Cubic Feet

SIC - Standard Industrial Classification

SO<sub>2</sub> - Sulfur Dioxide TPY - Tons Per Year

TSP - Total Suspended Particulate VOC - Volatile Organic Compounds

# APPENDIX F

# **Permit Modifications**

DATE OF REVISION	SECTION NUMBER, CONDITION NUMBER	DESCRIPTION OF REVISION

Operating Permit Number: 95OPEP147 First Issued: March 3, 1998 Renewed: January 1, 2009